

IAQ GUIDELINES FOR OCCUPIED BUILDINGS UNDER CONSTRUCTION



ANSI/SMACNA 008-2008



SHEET METAL AND AIR CONDITIONING CONTRACTORS'
NATIONAL ASSOCIATION, INC.

www.smacna.org

IAQ GUIDELINES FOR OCCUPIED BUILDINGS UNDER CONSTRUCTION

SECOND EDITION – NOVEMBER, 2007



**SHEET METAL AND AIR CONDITIONING CONTRACTORS'
NATIONAL ASSOCIATION, INC.**

4201 Lafayette Center Drive
Chantilly, VA 20151-1209
www.smacna.org

IAQ GUIDELINES FOR OCCUPIED BUILDINGS UNDER CONSTRUCTION

COPYRIGHT © SMACNA 2006
All Rights Reserved
by

**SHEET METAL AND AIR CONDITIONING CONTRACTORS'
NATIONAL ASSOCIATION, INC.**

4201 Lafayette Center Drive
Chantilly, VA 20151-1209

Printed in the U.S.A.

FIRST EDITION – NOVEMBER, 1995
SECOND EDITION – NOVEMBER, 2007

Except as allowed in the Notice to Users and in certain licensing contracts, no part of this book may be reproduced, stored in a retrievable system, or transmitted, in any form or by any means, electronic, mechanical, photocopying, recording, or otherwise, without the prior written permission of the publisher.

FOREWORD

In an effort to provide SMACNA contractors, architects, engineers, building owners and managers, and the general construction industry with a researched, practical publication to assist in maintaining acceptable indoor air quality during building renovation, SMACNA's Building Services Committee developed the first edition of the *IAQ Guidelines for Occupied Buildings Under Construction*. This manual has its roots in a workshop that took place during the IAQ 1993 Conference that was co-sponsored by SMACNA and other professional organizations. As the conference progressed it became clear that, other than the combined experiences of the presenters and other specialized professionals in attendance, there was little published technical guidance that dealt with the potential health hazards and annoyances related to carrying on construction activity in occupied buildings.

This second edition of the IAQ Guideline has been updated and was passed through an additional review process using a canvass review that meets SMACNA's American National Standards Institute (ANSI) accredited procedures. The ANSI process assures that interested and affected parties have an opportunity to review, comment, and approve publications as an ANSI standard document via a consensus process.

The IAQ Guideline is intended to be an authoritative source for providing project management guidance in maintaining satisfactory indoor air quality (IAQ) of occupied buildings undergoing renovation or construction. The Guideline covers how to manage the source of air pollutants, control measures, quality control and documentation, communication with occupants. It includes example projects, tables, references, resources, and checklists. The previous edition of the IAQ Guideline is referenced by the U.S. Green Building Council's LEED Green Building Rating System for Existing Buildings and New Construction. SMACNA recommends the guide to architects, engineers, construction managers, facility managers and building owners who will be involved in construction activities inside occupied buildings. Additionally, the principles presented here are also applicable to IAQ problems encountered in occupied areas of buildings during the final phases of new construction.

Methods to identify and remediate lead, asbestos, or other materials that are classified as hazardous materials are not intended to be within the scope of this standard.

SHEET METAL AND AIR CONDITIONING CONTRACTORS'
NATIONAL ASSOCIATION, INC.



TASK FORCE

Michael F. Mamayek, *Chairman*
Illingworth Corporation
Milwaukee, WI

Phil Corbin
J. F. Ahern Co.
Fond Du Lac, WI

Richard Lackey
Lackey Sheet Metal L.L.C.
Saint Louis, MO

Joseph R. Lansdell
Poynter Sheet Metal, Inc.
Bloomington, IN

Peyton Collie, *Staff Liaison*
SMACNA
Chantilly, VA

TECHNICAL AUTHOR

Ed Light, CIH
Building Dynamics, LLC
Ashton, MD



NOTICE TO USERS OF THIS PUBLICATION

1. DISCLAIMER OF WARRANTIES

- a) The Sheet Metal and Air Conditioning Contractors' National Association ("SMACNA") provides its product for informational purposes.
- b) The product contains "Data" which is believed by SMACNA to be accurate and correct but the data, including all information, ideas and expressions therein, is provided strictly "AS IS," with all faults. SMACNA makes no warranty either express or implied regarding the Data and SMACNA EXPRESSLY DISCLAIMS ANY IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR PARTICULAR PURPOSE.
- c) By using the data contained in the product user accepts the Data "AS IS" and assumes all risk of loss, harm or injury that may result from its use. User acknowledges that the Data is complex, subject to faults and requires verification by competent professionals, and that modification of parts of the Data by user may impact the results or other parts of the Data.
- d) IN NO EVENT SHALL SMACNA BE LIABLE TO USER, OR ANY OTHER PERSON, FOR ANY INDIRECT, SPECIAL OR CONSEQUENTIAL DAMAGES ARISING, DIRECTLY OR INDIRECTLY, OUT OF OR RELATED TO USER'S USE OF SMACNA'S PRODUCT OR MODIFICATION OF DATA THEREIN. This limitation of liability applies even if SMACNA has been advised of the possibility of such damages. IN NO EVENT SHALL SMACNA'S LIABILITY EXCEED THE AMOUNT PAID BY USER FOR ACCESS TO SMACNA'S PRODUCT OR \$1,000.00, WHICHEVER IS GREATER, REGARDLESS OF LEGAL THEORY.
- e) User by its use of SMACNA's product acknowledges and accepts the foregoing limitation of liability and disclaimer of warranty and agrees to indemnify and hold harmless SMACNA from and against all injuries, claims, loss or damage arising, directly or indirectly, out of user's access to or use of SMACNA's product or the Data contained therein.

2. ACCEPTANCE

This document or publication is prepared for voluntary acceptance and use within the limitations of application defined herein, and otherwise as those adopting it or applying it deem appropriate. It is not a safety standard. Its application for a specific project is contingent on a designer or other authority defining a specific use. SMACNA has no power or authority to police or enforce compliance with the contents of this document or publication and it has no role in any representations by other parties that specific components are, in fact, in compliance with it.

3. AMENDMENTS

The Association may, from time to time, issue formal interpretations or interim amendments, which can be of significance between successive editions.

4. PROPRIETARY PRODUCTS

SMACNA encourages technological development in the interest of improving the industry for the public benefit. SMACNA does not, however, endorse individual manufacturers or products.

5. FORMAL INTERPRETATION

a) A formal interpretation of the literal text herein or the intent of the technical committee or task force associated with the document or publication is obtainable only on the basis of written petition, addressed to the Technical Resources Department and sent to the Association's national office in Chantilly, Virginia. In the event that the petitioner has a substantive disagreement with the interpretation, an appeal may be filed with the Technical Resources Committee, which has technical oversight responsibility. The request must pertain to a specifically identified portion of the document that does not involve published text which provides the requested information. In considering such requests, the Association will not review or judge products or components as being in compliance with the document or publication. Oral and written interpretations otherwise obtained from anyone affiliated with the Association are unofficial. This procedure does not prevent any committee or task force chairman, member of the committee or task force, or staff liaison from expressing an opinion on a provision within the document, provided that such person clearly states that the opinion is personal and does not represent an official act of the Association in any way, and it should not be relied on as such. The Board of Directors of SMACNA shall have final authority for interpretation of this standard with such rules or procedures as they may adopt for processing same.

b) SMACNA disclaims any liability for any personal injury, property damage, or other damage of any nature whatsoever, whether special, indirect, consequential or compensatory, direct or indirectly resulting from the publication, use of, or reliance upon this document. SMACNA makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

6. APPLICATION

a) Any standards contained in this publication were developed using reliable engineering principles and research plus consultation with, and information obtained from, manufacturers, users, testing laboratories, and others having specialized experience. They are



subject to revision as further experience and investigation may show is necessary or desirable. Construction and products which comply with these Standards will not necessarily be acceptable if, when examined and tested, they are found to have other features which impair the result contemplated by these requirements. The Sheet Metal and Air Conditioning Contractors' National Association and other contributors assume no responsibility and accept no liability for the application of the principles or techniques contained in this publication. Authorities considering adoption of any standards contained herein should review all federal, state, local, and contract regulations applicable to specific installations.

b) In issuing and making this document available, SMACNA is not undertaking to render professional or other services for or on behalf of any person or entity. SMACNA is not undertaking to perform any duty owed to any person or entity to someone else. Any person or organization using this document should rely on his, her or its own judgement or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstance.

7. REPRINT PERMISSION

Non-exclusive, royalty-free permission is granted to government and private sector specifying authorities to reproduce *only* any construction details found herein in their specifications and contract drawings prepared for receipt of bids on new construction and renovation work within the United States and its territories, provided that the material copied is unaltered in substance and that the reproducer assumes all liability for the specific application, including errors in reproduction.

8. THE SMACNA LOGO

The SMACNA logo is registered as a membership identification mark. The Association prescribes acceptable use of the logo and expressly forbids the use of it to represent anything other than possession of membership. Possession of membership and use of the logo in no way constitutes or reflects SMACNA approval of any product, method, or component. Furthermore, compliance of any such item with standards published or recognized by SMACNA is not indicated by presence of the logo.

TABLE OF CONTENTS

FOREWORD	iii
TASK FORCE	iv
NOTICE TO USERS	v
TABLE OF CONTENTS	vii
CHAPTER 1 INTRODUCTION	Page
1.1 OVERVIEW	1.1
1.2 HOW TO USE THIS MANUAL	1.1
CHAPTER 2 AIR POLLUTANTS ASSOCIATED WITH CONSTRUCTION	
2.1 SOURCES OF AIRBORNE CONTAMINANTS	2.1
2.2 HOW CONTAMINANTS MOVE THROUGH BUILDINGS	2.3
2.3 HOW AIRBORNE CONTAMINANTS IMPACT BUILDING OCCUPANTS	2.5
2.4 PLACING CONTAMINANT EXPOSURES IN PERSPECTIVE	2.6
2.5 HAZARD ASSESSMENT	2.7
CHAPTER 3 CONTROL MEASURES	
3.1 OVERVIEW	3.1
3.2 HVAC PROTECTION	3.1
3.3 SOURCE CONTROL	3.1
3.4 PATHWAY INTERRUPTION	3.2
3.5 HOUSEKEEPING	3.3
3.6 SCHEDULING	3.4
3.7 OCCUPANT RELOCATION	3.4
CHAPTER 4 HVAC	
4.1 HVAC: A CRITICAL FACTOR IN CONSTRUCTION CONTROL	4.1
4.2 HVAC PROTECTION	4.1
4.3 HVAC SCHEDULING	4.3
4.4 EQUIPMENT CLEANING	4.3
4.5 ESTABLISHING PRESSURIZATION	4.3
CHAPTER 5 MANAGING THE CONSTRUCTION PROCESS	
5.1 PROJECT ORGANIZATION	5.1
5.2 SELECTING IAQ CONTROLS	5.2
CHAPTER 6 PRE-RENOVATION BUILDING EVALUATION	
6.1 OBJECTIVES	6.1
6.2 PROCEDURES	6.1
6.3 FOLLOW-UP	6.1



CHAPTER 7	CONTAINMENT	Page
7.1	GENERAL CONSIDERATIONS	7.1
7.2	GUIDELINES	7.1
7.3	BASIC CONTAINMENT	7.1
7.4	INTERMEDIATE CONTAINMENT	7.1
7.5	ADVANCED CONTAINMENT	7.2
CHAPTER 8	MOISTURE AND MOLD CONTROL	
8.1	GENERAL CHARACTERISTICS OF MOLD	8.1
8.2	MOISTURE PROBLEMS ASSOCIATED WITH CONSTRUCTION	8.1
8.3	PREVENTING MOLD GROWTH	8.1
8.4	MOLD CLEANUP ISSUES	8.2
CHAPTER 9	QUALITY CONTROL	
9.1	STANDARDS	9.1
9.2	SURVEILLANCE CRITERIA	9.1
9.3	ENFORCING WORK PRACTICES	9.2
9.4	REOCCUPANCY CRITERIA	9.2
9.5	PROJECT DOCUMENTATION	9.3
CHAPTER 10	COMMUNICATING WITH OCCUPANTS	
10.1	OCCUPANT EDUCATION	10.1
10.2	COMPLAINT RESPONSE	10.1
CHAPTER 11	TROUBLESHOOTING	
11.1	TYPICAL COMPLAINT SCENARIOS	11.1
11.2	INVESTIGATION PROTOCOL	11.1
11.3	DEVELOPING CONCLUSIONS	11.1
CHAPTER 12	EXAMPLES	
12.1	MINOR OFFICE RECONFIGURATION	12.1
12.2	ROOF REPLACEMENT	12.1
12.3	HOSPITAL RENOVATION	12.1
12.4	HIGH SCHOOL RENOVATION (TWO OPTIONS)	12.2
APPENDIX A	REFERENCES	
APPENDIX B	RESOURCES	
APPENDIX C	PLANNING CHECKLIST	
APPENDIX D	INSPECTION CHECKLIST	



APPENDIX E	MODEL SPECIFICATION	Page
E.1	PROJECT REQUIREMENTS	E.1
E.2	SUBMITTALS	E.2
E.3	HVAC BASIC MATERIALS AND METHODS	E.3
APPENDIX F	EARLY START-UP OF PERMANENTLY INSTALLED HVAC SYSTEMS	
APPENDIX G	DUCT CLEANLINESS FOR NEW CONSTRUCTION GUIDELINES	



TABLE		Page
2-1	Other Contributors to Health Complaints Sometimes Attributed to Airborne Contaminants	2.6

FIGURE		
2-1	Common Pollutant Pathways From Construction Site	2.4



CHAPTER 1

INTRODUCTION

1.1 OVERVIEW

The purpose of this manual is to guide building managers and contractors on controlling construction contaminants so they do not impact building occupants.

Poor indoor air quality (IAQ) is more likely to impact the health of building occupants when construction and renovation projects occur in an occupied building. Dust and odors or other contaminants of concern migrating out of the work area and into occupied spaces can disrupt normal operation of the facility and, under worst case scenarios, cause injury or illness. While IAQ concerns in most buildings are often comfort issues, environmental changes in occupied buildings undergoing construction can have much more serious consequences. The mere presence of detectable dust or odor from a construction project, even at harmless levels, may trigger occupant concerns based on perceived hazards.

Effective management of IAQ during construction requires designers, contractors, facility managers, building engineers, and the occupants to plan and work together. Conflicts regarding scheduling, budget, and continuing facility operation are best resolved early in the design development phase. Waiting for a mid-project air quality “crisis,” either real or perceived, can be costly to all parties. For example, implementing site controls and rescheduling contractors after the project is underway can be highly disruptive.

The expertise of architects, construction managers, heating, ventilation, and airconditioning (HVAC) engineers, and contractors are essential to the solution of most IAQ problems related to construction. Design of interior construction projects should include a detailed assessment of HVAC systems and relative pressurization, including their relationship to the proposed work. Where steps must be taken to protect building occupants from construction emissions, modifying HVAC operation and protecting the HVAC equipment and air conveyance system are often integral parts of the process.

A good construction manager should be trained to recognize activities or conditions which could be detrimental to building occupants. This awareness has become even more critical with the emergence of IAQ-related litigation. While standards for non-occupational air quality are not defined by either OSHA or EPA, specifications in construction contracts or facility leases may address IAQ. In practice, however, IAQ controls are usually based on common sense and good professional judgment. Ongoing documentation of

these decisions made to control IAQ and site conditions may be necessary to demonstrate good faith in regard to potential liability. Even where the best IAQ controls are in place, clear communication between all parties and flexibility to adapt to changing conditions are required for successful resolution of problems.

Construction activities potentially impact occupants both in new buildings where work is ongoing after some areas are occupied and in older facilities which are being repaired, modernized, or reconfigured. This manual will focus on those activities that temporarily produce airborne dust, odor, and other contaminants during demolition, construction, and punch list activities. Longer term IAQ concerns, such as proper design and modification of HVAC systems, are beyond the scope of this manual. The reader is referred to other references published by SMACNA, ASHRAE, and EPA for information on other IAQ issues.

1.2 HOW TO USE THIS MANUAL

No two construction projects are exactly alike. This manual, therefore, emphasizes general concepts and approaches from which the reader can select solutions best suited to a given site (combining these control measures with other construction and facility management requirements depends on an understanding of the entire process).

The remainder of this manual is organized to help answer the following questions:

Chapter

- 2.0 What are the common sources of airborne contaminants during construction?

How do air pollutants move through a building during construction?

How may dust and odors or other contaminants of concern from construction sites impact building occupants?

What are the relative risks of exposure to construction contaminants?

- 3.0 What options are available for protecting IAQ during building construction?

- 4.0 How do the design and operation of HVAC systems affect air quality during construction?

