

AMCA Publication 501-09

Application Manual for Air Louvers



**AIR MOVEMENT AND CONTROL
ASSOCIATION INTERNATIONAL, INC.**

The International Authority on Air System Components

AMCA Publication 501-09

Application Manual for Louvers



Air Movement and Control Association International, Inc.
30 W. University Drive
Arlington Heights, Illinois
60004

AMCA Publications

Authority AMCA Publication 501-09 was adopted by the membership of the Air Movement and Control Association, Inc. on February 21, 2009.

Copyright © 2009 by Air Movement and Control Association International, Inc.

All rights reserved. Reproduction or translation of any part of this work beyond that permitted by Sections 107 and 108 of the United States Copyright Act without the permission of the copyright owner is unlawful. Requests for permission or further information should be addressed to the Executive Director, Air Movement and Control Association International, Inc. at 30 West University Drive, Arlington Heights, IL 60004-1893 U.S.A.

Objections Air Movement and Control Association International, Inc. will consider and decide all written complaints regarding its standards, certification programs, or interpretations thereof. For information on procedures for submitting and handling complaints, write to:

Air Movement and Control Association International
30 West University Drive
Arlington Heights, IL 60004-1893 U.S.A.

AMCA International, Incorporated
c/o Federation of Environmental Trade Associations
2 Waltham Court, Milley Lane, Hare Hatch
Reading, Berkshire, United Kingdom
RG10 9TH

Disclaimer AMCA uses its best efforts to produce standards for the benefit of the industry and the public in light of available information and accepted industry practices. However, AMCA does not guarantee, certify or assure the safety or performance of any products, components or systems tested, designed, installed or operated in accordance with AMCA standards or that any tests conducted under its standards will be non-hazardous or free from risk.

Review Committee

Mike Watz Committee Chair	Greenheck Fan Corporation
Bob Van Becelaere	Ruskin Company
Mike Binkholder	Mestek, Inc.
Dane Carey	United Enertech
Randal Geedey	The Airolite Company, LLC
Eric Gohring	Louvers and Dampers, Inc.
Loren Rasmusson	Industrial Louvers, Inc.
Tim Orris	AMCA International
John Pakan	AMCA International

Related AMCA Documents

AMCA Standard 500-L	<i>Laboratory Methods of Testing Louvers for Rating</i>
AMCA Publication 511	<i>Certified Ratings Program for Air Control Devices</i>
AMCA Standard 540	<i>Test Method for Louvers Impacted by Wind Borne Debris</i>
AMCA Standard 550	<i>Test Method for High Velocity Wind Driven Rain Resistant Louvers</i>
AMCA Publication 111	<i>Laboratory Accreditation Program</i>

Contents

1. Purpose	1
2. Scope	1
3. Definitions	1
4. Application	2
4.1 Air moving systems	2
4.2 Architectural aesthetics	2
5. Louver Designs	2
5.1 Frames	2
5.2 Blades	2
5.3 Special application louvers	5
5.4 Special screens	7
5.5 Specialty shaped louvers	7
6. Testing and Certification	7
6.1 ANSI/AMCA Standard 500-L Testing	7
6.2 AMCA Publication 511 Certification	9
7. System Effects	10
7.1 Inlet & outlet conditions	10
7.2 Accessories	10
7.3 Wind velocities	10
8. Louver Selection	10
8.1 Determination of performance	10
8.2 Louver available free area determination	10
8.3 Air performance pressure drop	11
8.4 Water penetration performance	11
8.5 Air leakage determination (closed adjustable blade or combination louvers only)	11
8.6 Penthouse sizing	11
9. Basic Construction	20
9.1 Materials	20
9.2 Fabrication methods	20

9.3	Structural support	.21
9.4	Louver structurals - calculations	.21
10.	Accessories	.22
10.1	Sill extensions and flashing	.22
10.2	Subframes	.22
10.3	Actuators	.22
10.4	Mullion covers / batten plates	.22
10.5	Screens and grilles	.22
10.6	Blank-off panels	.22
10.7	Filters	.24
10.8	Gaskets and seals	.24
10.9	Security bars	.24
11.	Finishes	.24
11.1	Mill finish	.24
11.2	Prime coat	.24
11.3	Clear anodize	.24
11.4	Color anodize	.24
11.5	Baked enamel	.25
11.6	Fluorocarbon coatings	.25
11.7	Powdered coatings	.25
12.	Installation Methods	.25
12.1	Masonry	.25
12.2	Metal subframe	.25
12.3	Structural steel	.25
12.4	Wood frames	.25
12.5	Free standing columns	.25
12.6	Roof curbs for penthouses	.25

Application Manual for Louvers

1. Purpose

The intent of this publication is to provide information and important points to be considered when designing or specifying installations requiring louvers. It is not the purpose of this manual to be used for detailed specifications. However, it serves as a guide toward understanding the various types of louvers available and includes items to be considered to ensure their proper use.

2. Scope

This publication outlines the application of louvers including selection for pressure drop, air leakage, water penetration, and sound reduction. Examples of louver selection are included. An important section, System Effects, should not be overlooked when applying performance data (see Section 7). For information on testing, see Section 6.1; for information on certified ratings, see Section 6.2.

Common industry practices in louver construction, mounting, and suggested fastening methods for typical structures have been included to assist the installer.

3. Definitions

Actuator (Operator)

A mechanical accessory item attached to an adjustable or combination louver that moves the blade(s) to either the open or closed position, or to an intermediate position for flow modulation. Actuators may be manually, electrically, pneumatically or hydraulically powered.

Blades

A bar, slat, or vane in a louver assembly usually mounted within a frame; normally provided in multiple quantities. Blades are installed parallel to each other so that they restrict passage of water, sound, airborne materials, and/or sightlines through the louver.

Certified rating

A published performance rating which AMCA International has licensed to bear the AMCA International Seal. Certifications available include, but are not limited to: air performance, sound performance, air leakage, water penetration, wind driven rain, airflow measurement performance, or any combination thereof.

Continuous line (continuous blade)

A louver constructed with blades that present uninterrupted horizontal or vertical lines to complement or enhance archi-

tectural features.

Core area

The product of the minimum height and minimum width of the front opening in the louver assembly with the louver blades removed.

Decibel

A dimensionless number expressing, in logarithmic terms, the levels of sound power or sound pressure.

Discharge loss coefficient

A comparison of the actual flow through the louver vs. the theoretical flow through an opening the same size as the louver.

Frame

The outermost structure of a louver assembly comprising the head, sill, and jambs joined together to support the blades.

Free area velocity

Rate of airflow through the free area of the louver.

Head

The upper or highest horizontal frame member of a louver.

Jackshaft

A common shaft used to operate blades in one or more louvers.

Jamb

The vertical frame member on the sides of a louver.

Louver

A device comprising multiple blades, which, when mounted in an opening, permits the flow of air but inhibits the entrance of water or other elements.

Louver (fixed)

A louver in which the blades are firmly secured in an open position.

Louver (adjustable)

A louver in which the blades may be rotated either manually or by mechanical means.

Louver gross area (face area)

Overall width times overall height of the louver frame.