

ANSI/AMCA Standard 500-D-12

Laboratory Methods of Testing Dampers for Rating

An American National Standard
Approved by ANSI on March 29, 2012



**AIR MOVEMENT AND CONTROL
ASSOCIATION INTERNATIONAL, INC.**

The International Authority on Air System Components

ANSI/AMCA Standard 500-D-12

Laboratory Methods of Testing Dampers for Rating



Air Movement and Control Association International
30 W. University Drive
Arlington Heights, Illinois
60004

AMCA Publications

Authority	AMCA Standard 500-D-07 was adopted by the membership of the Air Movement and Control Association International, Inc. on October 19, 2006. It was approved as an American National Standard by the American National Standards Institute (ANSI) and became effective on January 23, 2007. The 2012 revision was approved by the AMCA membership on August 29, 2011, and was also approved as an American National Standard on March 29, 2012.
Copyright	© 2012 by Air Movement and Control Association International, Inc. All rights reserved. Reproduction or translation of any part of this work beyond that permitted by Sections 107 and 108 of the United States Copyright Act without the permission of the copyright owner is unlawful. Requests for permission or further information should be addressed to the Executive Director, Air Movement and Control Association International, Inc. at 30 West University Drive, Arlington Heights, IL 60004-1893 U.S.A.
Objections	Air Movement and Control Association International, Inc. will consider and decide all written complaints regarding its standards, certification programs, or interpretations thereof. For information on procedures for submitting and handling complaints, write to: Air Movement and Control Association International 30 West University Drive Arlington Heights, IL 60004-1893 U.S.A. AMCA International, Incorporated c/o Federation of Environmental Trade Associations 2 Waltham Court, Milley Lane, Hare Hatch Reading, Berkshire, United Kingdom RG10 9TH
Disclaimer	AMCA uses its best efforts to produce standards for the benefit of the industry and the public in light of available information and accepted industry practices. However, AMCA does not guarantee, certify or assure the safety or performance of any products, components or systems tested, designed, installed or operated in accordance with AMCA standards or that any tests conducted under its standards will be non-hazardous or free from risk.

Review Committee

Dane Carey
Committee Chair

T. A. Morrison Company

Marty Gissel

Greenheck Fan Corporation

Eric Gohring

Cesco Products

Dan Huber

Ruskin Company

Ed Koop

Ruskin Company

Matt Remington

Pottorff

Bob Van Becelaere

Ruskin Company

John Young

Nailor

Tim Orris

AMCA International

John Pakan

AMCA International

Related AMCA Documents

Related Publications	AMCA Publication 502	<i>Damper Application Manual for Heating, Ventilation, and Air-Conditioning</i>
	AMCA Publication 503	<i>Fire, Ceiling (Radiation), Smoke, and Fire/Smoke Damper Application Manual</i>
	AMCA Publication 511	<i>Certified Ratings Program - Product Rating Manual for Air Control Devices</i>
Related Standards	ANSI/AMCA Standard 510	<i>Methods of Testing Heavy Duty Dampers for Rating</i>
	ANSI/AMCA Standard 520	<i>Laboratory Methods for Testing Actuators</i>

Contents

- 1. Purpose 1
- 2. Scope 1
- 3. Definitions / Units of Measurement / Symbols 1
 - 3.1 Definitions 1
 - 3.2 Units of measure 3
 - 3.3 Symbols and Subscripts 4
- 4. Instruments and Methods of Measurement 4
 - 4.1 Accuracy [4] 4
 - 4.2 Pressure 4
 - 4.3 Airflow rate 7
 - 4.4 Torque 8
 - 4.5 Air density 8
 - 4.6 Voltage 9
 - 4.7 Electrical meters 9
 - 4.8 Pneumatic actuator supply air pressure 9
 - 4.9 Pressure gauges 9
 - 4.10 Chronometers 9
 - 4.11 Velocity meters 9
- 5. Equipment and Setups 9
 - 5.1 Setups 9
 - 5.2 Ducts 9
 - 5.3 Chambers 9
 - 5.4 Variable supply and exhaust systems 10
- 6. Objective, Observations, and Conduct of Test 10
 - 6.1 Air performance - pressure drop test 10
 - 6.2 Airflow leakage rate using ambient air 13
 - 6.3 Airflow leakage rate using ambient or heated air [15] 16
 - 6.4 Dynamic closure test using ambient air 18
 - 6.5 Operational test using ambient air 20
 - 6.6 Damper dynamic operational torque 22
 - 6.7 Dynamic closure test using heated air 24
 - 6.8 Operational test using heated air 26
 - 6.9 Thermal Efficiency Test 29

7. Calculations	30
7.1 Calibration correction	30
7.2 Density and viscosity of air	30
7.3 Airflow rate at test conditions	31
7.4 Density correction	32
7.5 Continuity of mass flow	33
7.6 Airflow leakage - system leakage correction	33
7.7 Pressure drop - duct system correction	33
7.8 Airflow leakage - system leakage correction for elevated temperature leakage tests	34
7.9 Thermal efficiency	35
8. References	35
Annex A Presentation of Air Performance Results for Rating Purposes (Informative)	62
Annex B Bibliography (Informative)	63
Annex C Additional Damper Information (Informative)	64

Laboratory Methods of Testing Dampers for Rating

1. Purpose

The purpose of this standard is to establish uniform laboratory test methods for dampers. The characteristics to be determined include, as appropriate, air leakage, pressure drop, dynamic closure, and operational torque.

It is not the purpose of this standard to specify the testing procedures to be used for design, production, or field testing. Similarly, it is not the purpose of this standard to indicate or establish minimum or maximum performance ratings to be used for specifying these products.

2. Scope

This standard may be used as a basis for testing dampers when air is used as the test gas.

A test conducted in accordance with the requirements of this standard is intended to demonstrate the performance of a damper and is not intended to determine acceptability level for a damper. It is not within the scope of this standard to indicate the actual sequence of testing.

The parties to a test for guarantee purposes may agree to exceptions to this standard in writing prior to the test. However, only a test that does not violate any mandatory requirement of this standard shall be designated as a test conducted in accordance with this standard.

For more information on damper modulating control characteristics, see Annex C.

3. Definitions / Units of Measurement / Symbols

3.1 Definitions

3.1.1 Damper

A device mounted in a duct or opening which is used to vary the volume of air flowing through the duct or opening. It may be operated manually or mechanically and may have one or more blades.

3.1.1.1 Single blade damper

A damper having one blade.

3.1.1.2 Multi-blade damper

A damper having more than one blade. The damper is a parallel blade damper if the blades rotate in the same direction; and an opposed blade damper if adjacent blades rotate in opposite directions.

3.1.1.3 Curtain damper

A damper which uses a folded, interlocked series of blades.

3.1.1.4 Backdraft damper (shutter)

A backdraft damper is a damper which, when mounted in a duct or opening, permits the flow of air in one direction only. It is normally opened by the energy of the air stream, but may be opened and/or closed by mechanical means. A counter-balanced backdraft damper has weights and/or springs added to the blade or blades to facilitate or impede the opening or closing action.

3.1.2 Air control damper

A mechanical device which does not fit the definition of a damper and which when placed in a duct or opening is used to regulate airflow.

3.1.3 Free area

The minimum area through which air can pass. It is determined by multiplying the sum of the minimum distances between intermediate blades, top blade and head and bottom blade and sill, by the minimum distance between jambs. The percent of free area is the free area thus calculated, divided by the gross area of the air control damper $\times 100$. See damper cross-sections (Figure 1).

3.1.3.1 Free area velocity

Airflow through a damper divided by its free area.

3.1.4 Face area

The total cross-sectional area of a damper, duct or wall opening.

3.1.4.1 Face area velocity

Airflow through a damper divided by its face area.

3.1.5 Psychrometrics

3.1.5.1 Dry-bulb temperature (t_d)

Dry-bulb temperature is the air temperature measured by a dry temperature sensor.

3.1.5.2 Wet-bulb temperature (t_w)

Wet-bulb temperature is the temperature measured by a temperature sensor covered by a water-moistened wick and exposed to air in motion. When properly measured, it is a close approximation of the temperature of adiabatic saturation.

3.1.5.3 Total temperature (t_t)

The temperature which exists by virtue of the internal and