BS EN 61000-3-3:2013



BSI Standards Publication

Electromagnetic compatibility (EMC)

Part 3-3: Limits – Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤ 16 A per phase and not subject to conditional connection

bsi.

...making excellence a habit.™

National foreword

This British Standard is the UK implementation of EN 61000-3-3:2013. It is identical to IEC 61000-3-3:2013. It supersedes BS EN 61000-3-3:2008, which will be withdrawn on 18 June 2016.

The UK participation in its preparation was entrusted by Technical Committee GEL/210, EMC – Policy committee, to Subcommittee GEL/210/12, EMC basic, generic and low frequency phenomena Standardization.

A list of organizations represented on this subcommittee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2013.
Published by BSI Standards Limited 2013

ISBN 978 0 580 75782 2
ICS 33.100.10

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 September 2013.

Amendments/corrigenda issued since publication

Date	Text affected

EUROPEAN STANDARD

NORME EUROPÉENNE

EUROPÄISCHE NORM

EN 61000-3-3

August 2013

ICS 33.100.10

Supersedes EN 61000-3-3:2008

English version

Electromagnetic compatibility (EMC) - Part 3-3: Limits - Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤ 16 A per phase and not subject to conditional connection

(IEC 61000-3-3:2013)

Compatibilité électromagnétique (CEM) - Partie 3-3: Limites - Limitation des variations de tension, des fluctuations de tension et du papillotement dans les réseaux publics d'alimentation basse tension, pour les matériels ayant un courant assigné ≤ 16 A par phase et non soumis à un raccordement conditionnel (CEI 61000-3-3:2013)

Elektromagnetische Verträglichkeit (EMV) - Teil 3-3: Grenzwerte - Begrenzung von Spannungsänderungen, Spannungsschwankungen und Flicker in öffentlichen Niederspannungs-Versorgungsnetzen für Geräte mit einem Bemessungsstrom ≤ 16 A je Leiter, die keiner Sonderanschlussbedingung unterliegen (IEC 61000-3-3:2013)

This European Standard was approved by CENELEC on 2013-06-18. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

© 2013 CENELEC - All rights of exploitation in any form and by any means reserved worldwide for CENELEC members.

Ref. No. EN 61000-3-3:2013 E

Foreword

The text of document 77A/809/FDIS, future edition 3 of IEC 61000-3-3, prepared by SC 77A, "EMC - Low frequency phenomena", of IEC TC 77, "Electromagnetic compatibility" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61000-3-3:2013.

The following dates are fixed:

• latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement	(dop)	2014-03-18
• latest date by which the national standards conflicting with the document have to be withdrawn	(dow)	2016-06-18

This document supersedes EN 61000-3-3:2008.

EN 61000-3-3:2013 includes the following significant technical changes with respect to EN 61000-3-3:2008:

This edition takes account of the changes made in EN 61000-4-15:2011.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For the relationship with EU Directive(s) see informative Annex ZZ, which is an integral part of this document.

Endorsement notice

The text of the International Standard IEC 61000-3-3:2013 was approved by CENELEC as a European Standard without any modification.

Annex ZA
(normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

Publication	Year	Title	EN/HD	Year
IEC/TR 60725	-	Consideration of reference impedances and public supply network impedances for use in determining disturbance characteristics of electrical equipment having a rated current ≤ 75 A per phase	-	-
IEC 60974-1	-	Arc welding equipment - Part 1: Welding power sources	EN 60974-1	-
IEC 61000-3-2	-	Electromagnetic compatibility (EMC) - Part 3-2: Limits - Limits for harmonic current emissions (equipment input current ≤ 16 A per phase)	EN 61000-3-2	-
IEC 61000-3-11	-	Electromagnetic compatibility (EMC) - Part 3-11: Limits - Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems - Equipment with rated current ≤ 75 A and subject to conditional connection	EN 61000-3-11	-
IEC 61000-4-15 + corr. March	2010 2012	Electromagnetic compatibility (EMC) - Part 4-15: Testing and measurement techniques - Flickermeter - Functional and design specifications	EN 61000-4-15	2011

Annex ZZ
(informative)

Coverage of Essential Requirements of EU Directives

This European Standard has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association and within its scope the standard covers protection requirements of Annex I Article 1(a) of the EU Directive 2004/108/EC and protection requirements of Article 3.1(b) (emissions only) of the EU Directive 1999/5/EC.

Compliance with this standard provides one means of conformity with the specified essential requirements of the Directives concerned.

WARNING: Other requirements and other EU Directives may be applicable to the products falling within the scope of this standard.

CONTENTS

INTRODUCTION 6
1 Scope 7
2 Normative references 7
3 Terms and definitions 8
4 Assessment of voltage changes, voltage fluctuations and flicker 10
4.1 Assessment of a relative voltage change, $d(t)$ 10
4.2 Assessment of the short-term flicker value, P_{st} 10
4.2.1 General 10
4.2.2 Flickermeter 11
4.2.3 Simulation method 11
4.2.4 Analytical method 11
4.2.5 Use of P_{st} = 1 curve 12
4.3 Assessment of long-term flicker value, P_{lt} 12
5 Limits 12
6 Test conditions 13
6.1 General 13
6.2 Measurement uncertainty 14
6.3 Test supply voltage 14
6.4 Reference impedance 14
6.5 Observation period 14
6.6 General test conditions 15
Annex A (normative) Application of limits and type test conditions for specific equipment 19
Annex B (normative) Test conditions and procedures for measuring d_{max} voltage changes caused by manual switching 27
Annex C (informative) Determination of steady state voltage and voltage change characteristics, as defined in IEC 61000-4-15:2010 28
Annex D (informative) Input relative voltage fluctuation ΔV/V for P_{st} = 1,0 at output [IEC/TR 61000-3-7:2008] 33
Bibliography 34

Figure 1 – Reference network for single-phase and three-phase supplies derived from a three-phase, four-wire supply 16
Figure 2 – Curve for P_{st} = 1 for rectangular equidistant voltage changes 17
Figure 3 – Shape factors F for double-step and ramp-voltage characteristics 17
Figure 4 – Shape factors F for rectangular and triangular voltage characteristics 18
Figure 5 – Shape factor F for motor-start voltage characteristics having various front times 18
Figure C.1 – Evaluation of $U_{hp}(t)$ 32

Table 1 – Assessment method 11
Table A.1 – Test conditions for hotplates 19
Table A.2 – Electrode parameters 24
Table A.3 – Frequency factor R related to repetition rate "r" 25
Table C.1 – Test specification for d_c – d_{max} – $t_{d(t)} > 3{,}3$ % (from Table 12 of IEC 61000-4-15: 2010) 31
Table C.2 – Test specification for d_c – d_{max} – $t_{d(t)} > 3{,}3$ % (from Table 13 of IEC 61000-4-15: 2010) 31
Table D.1 – Input relative voltage fluctuation ΔV/V for P_{st} = 1,0 at output 33

INTRODUCTION

IEC 61000 is published in separate parts according to the following structure:

Part 1: General

General considerations (introduction, fundamental principles)

Definitions, terminology

Part 2: Environment

Description of the environment

Classification of the environment

Compatibility levels

Part 3: Limits

Emission limits

Immunity limits (in so far as they do not fall under the responsibility of product committees)

Part 4: Testing and measurement techniques

Measurement techniques

Testing techniques

Part 5: Installation and mitigation guidelines

Installation guidelines

Mitigation methods and devices

Part 9: Miscellaneous

Each part is further subdivided into sections which are to be published either as International Standards or as Technical Reports.

These standards and reports will be published in chronological order and numbered accordingly.

ELECTROMAGNETIC COMPATIBILITY (EMC) –

Part 3-3: Limits – Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤ 16 A per phase and not subject to conditional connection

1 Scope

This part of IEC 61000 is concerned with the limitation of voltage fluctuations and flicker impressed on the public low-voltage system.

It specifies limits of voltage changes which may be produced by an equipment tested under specified conditions and gives guidance on methods of assessment.

This part of IEC 61000 is applicable to electrical and electronic equipment having an input current equal to or less than 16 A per phase, intended to be connected to public low-voltage distribution systems of between 220 V and 250 V line to neutral at 50 Hz, and not subject to conditional connection.

Equipment which does not comply with the limits of this part of IEC 61000 when tested with the reference impedance Z_{ref} of 6.4, and which therefore cannot be declared compliant with this part, may be retested or evaluated to show conformity with IEC 61000-3-11. Part 3-11 is applicable to equipment with rated input current ≤ 75 A per phase and subject to conditional connection.

The tests according to this part are type tests. Particular test conditions are given in Annex A and the test circuit is shown in Figure 1.

NOTE 1 The limits in this standard relate to the voltage changes experienced by consumers connected at the interface between the public supply low-voltage network and the equipment user's installation. Consequently, if the actual impedance of the supply at the supply terminals of equipment connected within the equipment user's installation exceeds the test impedance, it is possible that supply disturbance exceeding the limits could occur.

NOTE 2 The limits in this standard are based mainly on the subjective severity of flicker imposed on the light from 230 V 60 W coiled-coil filament lamps by fluctuations of the supply voltage. For systems with nominal voltage less than 220 V line to neutral and/or frequency of 60 Hz, the limits and reference circuit values are under consideration.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC/TR 60725, *Consideration of reference impedances and public supply impedances for use in determining disturbance characteristics of electrical equipment having a rated current ≤ 75 A per phase*

IEC 60974-1, *Arc welding equipment – Part 1: Welding power sources*

IEC 61000-3-2, *Electromagnetic compatibility (EMC) – Part 3-2: Limits – Limits for harmonic current emissions (equipment input current ≤ 16 A per phase)*