

ANSI/IEC 60529-2004

American National
Standard - Degrees of
Protection Provided by
Enclosures (IP Code)
(identical national
adoption)





ANSI/IEC 60529-2004

American National Standard

Degrees of Protection Provided
by Enclosures (IP Code)
(identical national adoption)



**ANSI Approval Date
November 3, 2004**

ANSI/IEC 60529-2004

*Degrees of Protection Provided by Enclosures (IP Code)
(identical national adoption)*

Published by:

National Electrical Manufacturers Association

1300 North 17th Street, Suite 1847
Rosslyn, Virginia 22209

www.nema.org

© Copyright 2004 by the National Electrical Manufacturers Association. All rights including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

AMERICAN NATIONAL STANDARD

Approval of an American National Standard requires verification by ANSI that the requirements for due process, consensus, and other criteria for approval have been met by the standards developer.

Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made toward their resolution.

The use of American National Standards is completely voluntary; their existence does not in any respect preclude anyone, whether he has approved the standards or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standards.

The American National Standards Institute does not develop standards and will in no circumstances give an interpretation of any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on the title page of this standard.

Caution Notice: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken periodically to reaffirm, revise, or withdraw this standard. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, 11 West 42nd Street, New York, NY, 10036, phone (212) 642-4900.

Published by

**National Electrical Manufacturers Association
1300 North 17th Street, Rosslyn, VA 22209**

© Copyright 2004 by the National Electrical Manufacturers Association.
All rights including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention or the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Printed in the United States of America

NOTICE AND DISCLAIMER
(ANSI Adoption of IEC Standards)

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

American National Standards, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. This publication was reviewed and approved under the procedures of the American National Standards Institute whereby a standard developed by a technical committee of the International Electrotechnical Commission (IEC) was adopted as an American National Standard. NEMA administered the process in accordance with the procedures of the American National Standards Institute to promote fairness in the development of consensus. As a publisher of this document, NEMA does not write the document and it does not independently test, evaluate or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications.

NEMA disclaims liability for any personal injury, property or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, express or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer's or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test or inspect products, designs or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

INTRODUCTION

This standard describes a system for classifying the degrees of protection provided by enclosures of electrical equipment for two conditions: 1) the protection of persons against access to hazardous parts and protection of equipment against the ingress of solid foreign objects and 2) the ingress of water. The degree of protection against these two conditions is designated by an IP Code.

Enclosures as used in this standard are as defined in the standard. This includes not only traditional metallic or polymeric enclosures but any enclosing part of electrical equipment that provides a degree of protection as defined in the scope. As such the use of this system allows specific ratings to be applied to different parts of the equipment. For example a component with an IP20 rating indicating only a degree of protection against contact with live parts within that component could be used within an overall enclosure with an IP43 rating that provides a degree of protection against probes and solid foreign objects as well as splashing water.

While the IP Code system is suitable for most types of electrical equipment, it must be noted that this standard is a horizontal standard and not a product standard. The product standards for different equipment may include other requirements for enclosures Types. The determination of the acceptability of the IP Code system as well as the applicability and use of these requirements is a subject for the end product standard. This system is only acceptable when adopted by the end product standard and as specified in the end product standard.


INTERNATIONAL STANDARD

IEC
60529

Edition 2.1
2001-02

Edition 2:1989 consolidated with amendment 1:1999

Degrees of protection provided by enclosures (IP Code)



Reference number
IEC 60529:1989+A1:1999(E)

Publication numbering

As from 1 January 1997 all IEC publications are issued with a designation in the 60000 series. For example, IEC 34-1 is now referred to as IEC 60034-1.

Consolidated editions

The IEC is now publishing consolidated versions of its publications. For example, edition numbers 1.0, 1.1 and 1.2 refer, respectively, to the base publication, the base publication incorporating amendment 1 and the base publication incorporating amendments 1 and 2.

Further information on IEC publications

The technical content of IEC publications is kept under constant review by the IEC, thus ensuring that the content reflects current technology. Information relating to this publication, including its validity, is available in the IEC Catalogue of publications (see below) in addition to new editions, amendments and corrigenda. Information on the subjects under consideration and work in progress undertaken by the technical committee which has prepared this publication, as well as the list of publications issued, is also available from the following:

- **IEC Web Site** (www.iec.ch)

- **Catalogue of IEC publications**

The on-line catalogue on the IEC web site (www.iec.ch/searchpub) enables you to search by a variety of criteria including text searches, technical committees and date of publication. On-line information is also available on recently issued publications, withdrawn and replaced publications, as well as corrigenda.

- **IEC Just Published**

This summary of recently issued publications (www.iec.ch/online_news/justpub) is also available by email. Please contact the Customer Service Centre (see below) for further information.

- **Customer Service Centre**

If you have any questions regarding this publication or need further assistance, please contact the Customer Service Centre:

Email: custserv@iec.ch

Tel: +41 22 919 02 11

Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

IEC 60529

Edition 2.1
2001-02

Edition 2:1989 consolidated with amendment 1:1999

Degrees of protection provided by enclosures (IP Code)

© IEC 2001 Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembé, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

PRICE CODE

X

For price, see current catalogue

CONTENTS

	Page
FOREWORD.....	6
INTRODUCTION.....	7
Clause	
1 Scope and object.....	8
2 Normative references	9
3 Definitions	9
4 Designations	11
4.1 Arrangement of the IP Code.....	11
4.2 Elements of the IP Code and their meanings	12
4.3 Examples for the use of letters in the IP Code	13
5 Degrees of protection against access to hazardous parts and against solid foreign objects indicated by the first characteristic numeral.....	13
5.1 Protection against access to hazardous parts.....	13
5.2 Protection against solid foreign objects	14
6 Degrees of protection against ingress of water indicated by the second characteristic numeral	15
7 Degrees of protection against access to hazardous parts indicated by the additional letter	17
8 Supplementary letters.....	18
9 Examples of designations with the IP Code	18
9.1 IP Code not using optional letters:	18
9.2 IP Code using optional letters:	19
10 Marking	19
11 General requirements for tests.....	20
11.1 Atmospheric conditions for water or dust tests.....	20
11.2 Test samples	20
11.3 Application of test requirements and interpretation of test results.....	20
11.4 Combination of test conditions for the first characteristic numeral	20
11.5 Empty enclosures	21
12 Tests for protection against access to hazardous parts indicated by the first characteristic numeral	21
12.1 Access probes	21
12.2 Test conditions	21
12.3 Acceptance conditions	23
12.3.1 For low-voltage equipment (rated voltages not exceeding 1 000 V a.c. and 1 500 V d.c.).....	23
12.3.2 For high-voltage equipment (rated voltages exceeding 1 000 V a.c. and 1 500 V d.c.)	23
12.3.3 For equipment with hazardous mechanical parts	23

Clause	Page
13 Tests for protection against solid foreign objects indicated by the first characteristic numeral	24
13.1 Test means	24
13.2 Test conditions for first characteristic numerals 1, 2, 3, 4.....	24
13.3 Acceptance conditions for first characteristic numerals 1, 2, 3, 4.....	24
13.4 Dust test for first characteristic numerals 5 and 6	24
13.5 Special conditions for first characteristic numeral 5	26
13.5.1 Test conditions for first characteristic numeral 5	26
13.5.2 Acceptance conditions for first characteristic numeral 5	26
13.6 Special conditions for first characteristic numeral 6	26
13.6.1 Test conditions for first characteristic numeral 6	26
13.6.2 Acceptance conditions for first characteristic numeral 6	26
14 Tests for protection against water indicated by the second characteristic numeral.....	26
14.1 Test means	26
14.2 Test conditions	27
14.2.1 Test for second characteristic numeral 1 with the drip box	28
14.2.2 Test for second characteristic numeral 2 with the drip box	28
14.2.3 Test for second characteristic numeral 3 with oscillating tube or spray nozzle	28
14.2.4 Test for second characteristic numeral 4 with oscillating tube or spray nozzle	29
14.2.5 Test for second characteristic numeral 5 with the 6,3 mm nozzle.....	30
14.2.6 Test for second characteristic numeral 6 with the 12,5 mm nozzle.....	30
14.2.7 Test for second characteristic numeral 7: temporary immersion between 0,15 m and 1 m	30
14.2.8 Test for second characteristic numeral 8: continuous immersion subject to agreement.....	31
14.3 Acceptance conditions	31
15 Tests for protection against access to hazardous parts indicated by the additional letter	31
15.1 Access probes	31
15.2 Test conditions	31
15.3 Acceptance conditions	32
Annex A (informative) Examples of IP coding for the verification of protection of low-voltage equipment against access to hazardous parts	39
Annex B (informative) Summary of responsibilities of relevant technical committees.....	45
Bibliography	47

	Page
Figure 1 – Jointed test finger.....	33
Figure 2 – Test device to verify protection against dust (dust chamber).....	34
Figure 3 – Test device to verify protection against vertically falling water drops (drip box)	35
Figure 4 – Test device to verify protection against spraying and splashing water; second characteristic numerals 3 and 4 (oscillating tube).....	36
Figure 5 – Hand-held device to verify protection against spraying and splashing water; second characteristic numerals 3 and 4 (spray nozzle)	37
Figure 6 – Test device to verify protection against water jets (hose nozzle).....	38
Table 1 – Degrees of protection against access to hazardous parts indicated by the first characteristic numeral.....	14
Table 2 – Degrees of protection against solid foreign objects indicated by the first characteristic numeral.....	15
Table 3 – Degrees of protection against water indicated by the second characteristic numeral.....	16
Table 4 – Degrees of protection against access to hazardous parts indicated by the additional letter.....	17
Table 5 – Test conditions for degrees of protection indicated by the first characteristic numeral.....	21
Table 6 – Access probes for the tests for protection of persons against access to hazardous parts.....	22
Table 7 – Test means for the tests for protection against solid foreign objects.....	24
Table 8 – Test means and main test conditions for the tests for protection against water.....	27
Table 9 – Total water flow rate q_V under IPX3 and IPX4 test conditions – Mean flow rate per hole $q_{Vl} = 0,07$ l/min	29
IP Codes of examples in annex A.....	44

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**DEGREES OF PROTECTION PROVIDED
BY ENCLOSURES (IP Code)**

FOREWORD

- 1) The IEC (International Electrotechnical Commission) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of the IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, the IEC publishes International Standards. Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. The IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of the IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested National Committees.
- 3) The documents produced have the form of recommendations for international use and are published in the form of standards, technical specifications, technical reports or guides and they are accepted by the National Committees in that sense.
- 4) In order to promote international unification, IEC National Committees undertake to apply IEC International Standards transparently to the maximum extent possible in their national and regional standards. Any divergence between the IEC Standard and the corresponding national or regional standard shall be clearly indicated in the latter.
- 5) The IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with one of its standards.
- 6) Attention is drawn to the possibility that some of the elements of this International Standard may be the subject of patent rights. The IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60529 has been prepared by technical committee 70: Degrees of protection by enclosures.

This second edition cancels and replaces the first edition published in 1976 and constitutes a technical revision.

This consolidated version of IEC 60529 is based on the second edition (1989) [documents 70(CO)13 + 70(CO)16 and 70(CO)15 + 70(CO)17], and its amendment 1 (1999) [documents 70/91/FDIS and 70/92/RVD].

It bears the edition number 2.1.

A vertical line in the margin shows where the base publication has been modified by amendment 1.

Annexes A and B are for information only.

The contents of the corrigendum of January 2003 have been included in this copy.

INTRODUCTION

This standard describes a system for classifying the degrees of protection provided by the enclosures of electrical equipment. Whilst this system is suitable for use with most types of electrical equipment, it should not be assumed that all the listed degrees of protection are applicable to a particular type of equipment. The manufacturer of the equipment should be consulted to determine the degrees of protection available and the parts of equipment to which the stated degree of protection applies.

The adoption of this classification system, wherever possible, will promote uniformity in methods of describing the protection provided by the enclosure and in the tests to prove the various degrees of protection. It should also reduce the number of types of test devices necessary to test a wide range of products.

This second edition of IEC 60529 takes account of experiences with the first edition, and clarifies the requirements. It provides for an optional extension of the IP Code by an additional letter A, B, C, or D if the actual protection of persons against access to hazardous parts is higher than that indicated by the first characteristic numeral.

In general, enclosures with an IP coding to the first edition would be eligible for the same code according to this edition.

DEGREES OF PROTECTION PROVIDED BY ENCLOSURES (IP Code)

1 Scope and object

This standard applies to the classification of degrees of protection provided by enclosures for electrical equipment with a rated voltage not exceeding 72,5 kV.

The object of this standard is to give:

- a) *Definitions* for degrees of protection provided by enclosures of electrical equipment as regards:
 - 1) protection of persons against access to hazardous parts inside the enclosure;
 - 2) protection of the equipment inside the enclosure against ingress of solid foreign objects;
 - 3) protection of the equipment inside the enclosure against harmful effects due to the ingress of water.
- b) *Designations* for these degrees of protection.
- c) *Requirements* for each designation.
- d) *Tests* to be performed to verify that the enclosure meets the requirements of this standard.

It will remain the responsibility of individual technical committees to decide on the extent and manner in which, the classification is used in their standards and to define “enclosure” as it applies to their equipment. However, it is recommended that for a given classification the tests do not differ from those specified in this standard. If necessary, complementary requirements may be included in the relevant product standard. A guide for the details to be specified in relevant product standards is given in annex B.

For a particular type of equipment, a technical committee may specify different requirements provided that at least the same level of safety is ensured.

This standard deals only with enclosures that are in all other respects suitable for their intended use as specified in the relevant product standard and which from the point of view of materials and workmanship ensure that the claimed degrees of protection are maintained under the normal conditions of use.

This standard is also applicable to empty enclosures provided that the general test requirements are met and that the selected degree of protection is suitable for the type of equipment to be protected.

Measures to protect both the enclosure and the equipment inside the enclosure against external influences or conditions such as

- mechanical impacts
- corrosion
- corrosive solvents (for example, cutting liquids)
- fungus
- vermin
- solar radiation
- icing
- moisture (for example, produced by condensation)
- explosive atmospheres

and the protection against contact with hazardous moving parts external to the enclosure (such as fans), are matters for the relevant product standard to be protected.