BS EN 61158-6-5:2014



BSI Standards Publication

Industrial communication networks — Fieldbus specifications

Part 6-5: Application layer protocol specification — Type 5 elements

bsi.

...making excellence a habit.™

National foreword

This British Standard is the UK implementation of EN 61158-6-5:2014. It is identical to IEC 61158-6-5:2014. It supersedes BS EN 61158-6-5:2008 which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee AMT/7, Industrial communications: process measurement and control, including fieldbus.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2014.
Published by BSI Standards Limited 2014

ISBN 978 0 580 79471 1
ICS 25.040.40; 35.100.70; 35.110

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 November 2014.

Amendments issued since publication

Date	Text affected

EUROPEAN STANDARD

NORME EUROPÉENNE

EUROPÄISCHE NORM

EN 61158-6-5

October 2014

ICS 25.040.40; 35.100.70; 35.110

Supersedes EN 61158-6-5:2008

English Version

Industrial communication networks - Fieldbus specifications - Part 6-5: Application layer protocol specification - Type 5 elements (IEC 61158-6-5:2014)

Réseaux de communication industriels - Spécifications des bus de terrain - Partie 6-5: Spécification du protocole de la couche application - Éléments de type 5 (CEI 61158-6-5:2014)

Industrielle Kommunikationsnetze - Feldbusse - Teil 6-5: Protokollspezifikation des Application Layer (Anwendungsschicht) - Typ 5-Elemente (IEC 61158-6-5:2014)

This European Standard was approved by CENELEC on 2014-09-23. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

© 2014 CENELEC All rights of exploitation in any form and by any means reserved worldwide for CENELEC Members.

Foreword

The text of document 65C/764/FDIS, future edition 2 of IEC 61158-6-5, prepared by SC 65C "Industrial networks" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61158-6-5:2014.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2015-06-23
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2017-09-23

This document supersedes EN 61158-6-5:2008.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association.

Endorsement notice

The text of the International Standard IEC 61158-6-5:2014 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61158-3-1	NOTE	Harmonized as EN 61158-3-1.
IEC 61158-4-1	NOTE	Harmonized as EN 61158-4-1.
IEC 61784-1	NOTE	Harmonized as EN 61784-1.
IEC 61784-2	NOTE	Harmonized as EN 61784-2.

Annex ZA
(normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

Publication	Year	Title	EN/HD	Year
IEC 61158-1	-	Industrial communication networks - Fieldbus specifications - Part 1: Overview and guidance for the IEC 61158 and IEC 61784 series	EN 61158-1	-
IEC 61158-5-5	-	Industrial communication networks - Fieldbus specifications - Part 5-5: Application layer service definition - Type 5 elements	EN 61158-5-5	-
ISO/IEC 7498-1	-	Information technology - Open Systems Interconnection - Basic Reference Model: The Basic Model	-	-
ISO/IEC 8825	1990	Information technology - Open Systems Interconnection - Specification of Basic Encoding Rules for Abstract Syntax Notation One (ASN.1)	-	-
ISO/IEC 9545	-	Information technology - Open Systems Interconnection - Application layer structure	-	-
ISO/IEC 10731	-	Information technology - Open Systems Interconnection - Basic Reference Model - Conventions for the definition of OSI services	-	-
IETF RFC 791	-	Internet Protocol	-	-

CONTENTS

INTRODUCTION 9
1 Scope 10
1.1 General 10
1.2 Specifications 11
1.3 Conformance 11
2 Normative references 11
3 Terms, definitions, symbols, abbreviations and conventions 12
3.1 Terms and definitions from other ISO/IEC standards 12
3.2 IEC 61158-1 terms 13
3.3 Abbreviations and symbols 16
3.4 Conventions 17
3.5 Conventions used in state machines 18
4 Protocol 19
4.1 Overview 19
4.2 FAL syntax description 19
4.3 Transfer syntax 19
4.4 FAL protocol state machine structure 71
4.5 SMK state machine 71
4.6 VCR state machine 88
4.7 FAL service protocol machine (FSPM) 89
4.8 Application relationship protocol machines (ARPMs) 89
4.9 DLL mapping protocol machine (DMPM) 103
Bibliography 108

Figure 1 – State transition diagram for SMK 73
Figure 2 – State transition diagram of client / server ARPM 92
Figure 3 – State transition diagram of the publisher / subscriber ARPM 98
Figure 4 – State transition diagram of DMPM 104

Table 1 – Conventions used for state machines 18
Table 2 – Data types 20
Table 3 – Data types 20
Table 4 – APDU header format 21
Table 5 – FDA address use 22
Table 6 – FDA address header field APDUs sent by a client VCR endpoint 23
Table 7 – FDA address header field APDUs sent by a server VCR endpoint 24
Table 8 – FDA address header field APDUs sent by a publisher VCR endpoint 24
Table 9 – FDA address header field APDUs sent by a report source VCR endpoint 25
Table 10 – APDU trailer fields 25
Table 11 – Request APDU parameters 28
Table 12 – SMK FDA address values 30
Table 13 – SMK FDA address values 30

Table 14 – Request APDU parameters 31
Table 15 – SMK FDA address values for SM identify 32
Table 16 – SMK FDA address values for SMK set assignment info request APDUs 33
Table 17 – SMK clear address request APDU parameters 33
Table 18 – SMK FDA address values for SMK set assignment info request APDUs 33
Table 19 – SMK set assignment info request APDU parameters 34
Table 20 – SMK set assignment info response APDU parameters 35
Table 21 – SMK FDA address values for SMK device clear assignment Info APDUs 36
Table 22 – SMK clear assignment info request APDU parameters 36
Table 23 – SMK FDA address values for SMK device annunciation request APDUs 36
Table 24 – SMK device annunciation request APDU parameters 37
Table 25 – Initiate request APDU parameters 39
Table 26 – Initiate response APDU parameters 40
Table 27 – Abort request APDU parameters 40
Table 28 – Get response APDU parameters 40
Table 29 – Identify response APDU parameters 41
Table 30 – Get OD request APDU parameters 41
Table 31 – Get OD response APDU parameters 41
Table 32 – Initiate put OD request APDU parameters 42
Table 33 – Put OD request APDU parameters 42
Table 34 – Generic initiate download sequence request APDU parameters 43
Table 35 – Generic download segment request APDU parameters 43
Table 36 – Generic terminate download sequence request APDU parameters 44
Table 37 – Response APDU parameters 44
Table 38 – Initiate download sequence request APDU parameters 44
Table 39 – Download segment request APDU parameters 45
Table 40 – Download segment response APDU parameters 45
Table 41 – Terminate download sequence request APDU parameters 45
Table 42 – Initiate upload sequence request APDU parameters 46
Table 43 – Upload segment request APDU parameters 46
Table 44 – Upload segment response APDU parameters 47
Table 45 – Terminate upload sequence request APDU parameters 47
Table 46 – Request domain download request APDU parameters 47
Table 47 – Request domain upload request APDU parameters 48
Table 48 – Create program invocation request APDU parameters 48
Table 49 – Create program invocation response APDU parameters 49
Table 50 – Delete program invocation request APDU parameters 49
Table 51 – Start request APDU parameters 49
Table 52 – Stop request APDU parameters 50
Table 53 – Resume request APDU parameters 50
Table 54 – Reset request APDU parameters 50
Table 55 – Kill request APDU parameters 51
Table 56 – Read request APDU parameters 51

Table 57 – Read response APDU parameters 51
Table 58 – Read with subindex request APDU parameters 52
Table 59 – Read with subindex response APDU parameters 52
Table 60 – Write request APDU parameters 52
Table 61 – Write with subindex request APDU parameters 52
Table 62 – Define variable list request APDU parameters 53
Table 63 – Define variable list response APDU parameters 53
Table 64 – Delete variable list request APDU parameters 53
Table 65 – Information report request APDU parameters 54
Table 66 – Information report with subindex request APDU parameters 54
Table 67 – Information report on change request APDU parameters 54
Table 68 – Information report on change with subindex request APDU parameters 55
Table 69 – Event notification request APDU parameters 55
Table 70 – Alter event condition monitoring request APDU parameters 55
Table 71 – Acknowledge event notification request APDU parameters 56
Table 72 – LAN redundancy diagnostic message request APDU parameters 56
Table 73 – LAN redundancy get information response APDU parameters 58
Table 74 – LAN redundancy get statistics request APDU parameters 59
Table 75 – Object description header 61
Table 76 – Null object 61
Table 77 – Structure of the list of object descriptions 62
Table 78 – Structure of a load region in the S-OD 62
Table 79 – Structure of a function invocation in the DP-OD 63
Table 80 – Structure of an event in the S-OD 64
Table 81 – Structure of a data type in the ST-OD 64
Table 82 – Structure of a data type structure description in the ST-OD 65
Table 83 – Structure of a simple variable in the S-OD 65
Table 84 – Structure of an array in the S-OD 66
Table 85 – Structure of a record in the S-OD 66
Table 86 – Structure of a variable list in the DV-OD 67
Table 87 – Common error parameters 68
Table 88 – PI error parameters 68
Table 89 – OD error parameters 68
Table 90 – Error class and error code values 69
Table 91 – SMKPM service primitives 72
Table 92 – SMKPM states 73
Table 93 – SMKPM state table – initialization 73
Table 94 – SMKPM state table – receive transitions 74
Table 95 – SMKPM state table – internal events 79
Table 96 – HseRepeatTimerExpires () 80
Table 97 – RcvNewNetworkAddress (interface, address) 80
Table 98 – RcvMsg () 80
Table 99 – SntpSyncLost () 80

Table 100 – AddressToClear (sm_svc) 81
Table 101 – AssignmentInfo_Set () 81
Table 102 – ConfigurationSessionActive () 81
Table 103 – DeviceRedundancyState () 81
Table 104 – DevId_Match (sm_svc) 82
Table 105 – DuplicateQueryIdMatch (sm_svc) 82
Table 106 – DuplicatePdTagDetected () 82
Table 107 – FdaAddressType (sm_svc) 82
Table 108 – IsValid (sm_svc) 83
Table 109 – NetworkAddressChange (interface, address) 83
Table 110 – NumberOfAssignedAddresses () 83
Table 111 – OperationalRestore () 83
Table 112 – PdTag_Match (sm_svc) 83
Table 113 – PdTagDeviceIndex_Check (sm_svc) 84
Table 114 – Query_Match (sm_svc) 84
Table 115 – QueryType (sm_svc) 84
Table 116 – SmCacheEntry (sm_svc) 84
Table 117 – Clear_Address (interface_to_clear) 85
Table 118 – Clear_DuplicatePdTagFlag () 85
Table 119 – Get_AddlCode () 85
Table 120 – New_Address (interface, address) 85
Table 121 – Restart_HseRepeatTimer () 86
Table 122 – Restore_Defaults () 86
Table 123 – Send_SM_CommonErrorRsp (sm_service_type, svc_spec_params) 86
Table 124 – Send_SM_ReqRspMessage (sm_svc) 86
Table 125 – Set_Assignment_Data (sm_svc) 86
Table 126 – Set_DuplicatePdTagFlag () 87
Table 127 – SvcType (sm_svc) 87
Table 128 – Additional code used by error class and code 87
Table 129 – Additional code parameter IDs 87
Table 130 – Primitives issued by FSPM to ARPM 89
Table 131 – Primitives issued by ARPM to FSPM 90
Table 132 – Parameters used with primitives exchanged between FSPM and ARPM 90
Table 133 – Client / Server ARPM states 92
Table 134 – Client / server ARPM state table – sender transitions 93
Table 135 – Client / server ARPM state table – receiver transitions 94
Table 136 – Primitives issued by FSPM to ARPM 96
Table 137 – Primitives issued by ARPM to FSPM 96
Table 138 – Parameters used with primitives exchanged between FSPM and ARPM 97
Table 139 – Publisher / subscriber ARPM states 98
Table 140 – MulticastARPM state table – sender transitions 99
Table 141 – MulticastARPM state table – receiver transitions 99
Table 142 – BuildFAL-ErrPDU() 100

Table 143 – BuildFAL-ReqRspPDU() 100
Table 144 – GetArepId() 100
Table 145 – ConfigurationArCheckOK() 100
Table 146 – FAL_Pdu_BufferSize() 100
Table 147 – FAL_Pdu_Confirmed() 101
Table 148 – FAL_Pdu_DuplicateMsg () 101
Table 149 – FAL_Pdu_GetVcrId() 101
Table 150 – FAL_Pdu_InactivityCloseTime() 101
Table 151 – FAL_Pdu_TransmitDelayTime() 101
Table 152 – FAL_Pdu_SvcType() 101
Table 153 – FAL_Pdu_RemoteAddress() 102
Table 154 – FAL_Pdu_TrailerFields() 102
Table 155 – FAL_Pdu_ServiceSpecificParameters() 102
Table 156 – FAL_Pdu_Valid() 102
Table 157 – MaxOutstandingReached() 102
Table 158 – StartInactivityCloseTimer() 102
Table 159 – Primitives issued by ARPM to DMPM 103
Table 160 – Primitives issued by DMPM to ARPM 103
Table 161 – Parameters used with primitives exchanged between ARPM and DMPM 103
Table 162 – Primitives exchanged between the socket model and DMPM 104
Table 163 – Parameters of DMPM/socket model primitives 104
Table 164 – DMPM state descriptions 104
Table 165 – DMPM state table – sender transitions 105
Table 166 – DMPM state table – receiver transitions 106
Table 167 – ConnectionOriented 106
Table 168 – GetBufferedData 106
Table 169 – GetConnectionId 106
Table 170 – LoadBuffer 107
Table 171 – RemainingBufferSizeCheck 107
Table 172 – StartTransmitDelayTimer 107

INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158-1.

The application protocol provides the application service by making use of the services available from the data-link or other immediately lower layer. The primary aim of this standard is to provide a set of rules for communication expressed in terms of the procedures to be carried out by peer application entities (AEs) at the time of communication. These rules for communication are intended to provide a sound basis for development in order to serve a variety of purposes:

- as a guide for implementors and designers;
- for use in the testing and procurement of equipment;
- as part of an agreement for the admittance of systems into the open systems environment;
- as a refinement to the understanding of time-critical communications within OSI.

This standard is concerned, in particular, with the communication and interworking of sensors, effectors and other automation devices. By using this standard together with other standards positioned within the OSI or fieldbus reference models, otherwise incompatible systems may work together in any combination.

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 6-5: Application layer protocol specification – Type 5 elements

1 Scope

1.1 General

The fieldbus Application Layer (FAL) provides user programs with a means to access the fieldbus communication environment. In this respect, the FAL can be viewed as a “window between corresponding application programs.”

This standard provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment and material specific to Type 5 fieldbus. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This standard defines in an abstract way the externally visible behavior provided by the Type 5 fieldbus Application Layer in terms of

a) the abstract syntax defining the application layer protocol data units conveyed between communicating application entities,
b) the transfer syntax defining the application layer protocol data units conveyed between communicating application entities,
c) the application context state machine defining the application service behavior visible between communicating application entities; and
d) the application relationship state machines defining the communication behavior visible between communicating application entities; and.

The purpose of this standard is to define the protocol provided to

1) define the wire-representation of the service primitives defined in IEC 61158-5-5, and
2) define the externally visible behavior associated with their transfer.

This standard specifies the protocol of the Type 5 IEC fieldbus Application Layer, in conformance with the OSI Basic Reference Model (ISO/IEC 7498-1) and the OSI Application Layer Structure (ISO/IEC 9545).

FAL services and protocols are provided by FAL application-entities (AE) contained within the application processes. The FAL AE is composed of a set of object-oriented Application Service Elements (ASEs) and a Layer Management Entity (LME) that manages the AE. The ASEs provide communication services that operate on a set of related application process object (APO) classes. One of the FAL ASEs is a management ASE that provides a common set of services for the management of the instances of FAL classes.

Although these services specify, from the perspective of applications, how request and responses are issued and delivered, they do not include a specification of what the requesting and responding applications are to do with them. That is, the behavioral aspects of the applications are not specified; only a definition of what requests and responses they can