

ENERGY SYSTEMS ANALYSIS AND MANAGEMENT MANUAL



**SHEET METAL AND AIR CONDITIONING CONTRACTORS'
NATIONAL ASSOCIATION, INC.**

www.smacna.org

ENERGY SYSTEMS ANALYSIS AND MANAGEMENT MANUAL

SECOND EDITION - 2014



**SHEET METAL AND AIR CONDITIONING CONTRACTORS'
NATIONAL ASSOCIATION, INC.**
4201 Lafayette Center Drive
Chantilly, VA 20151-1219
www.smacna.org

ENERGY SYSTEMS ANALYSIS AND MANAGEMENT MANUAL

COPYRIGHT © SMACNA 1997, 2014
All Rights Reserved
by

**SHEET METAL AND AIR CONDITIONING CONTRACTORS'
NATIONAL ASSOCIATION, INC.**

4201 Lafayette Center Drive
Chantilly, VA 20151-1219

Printed in the U.S.A.

FIRST EDITION – 1997
SECOND EDITION – 2014

ISBN 978-1-61721-105-8 Print
ISBN 978-1-61721-110-2 PDF

Except as allowed in the Notice to Users and in certain licensing contracts, no part of this book may be reproduced, stored in a retrievable system, or transmitted, in any form or by any means, electronic, mechanical, photocopying, recording, or otherwise, without the prior written permission of the publisher.

FOREWORD

This is the second edition of the Energy Systems Analysis And Management Manual with the first edition dating to 1997. In the years since the first edition many changes have been seen in the industry.

With the rising cost of fossil fuels and the increase of environmental concerns, reducing the energy consumption of HVAC systems is increasingly important. With these changes and with new changes coming on the horizon, the SMACNA contractor needs to be positioned to meet these challenges. New construction is only one part of the opportunities that are available for the contractor. Opportunities exist in other parts of the industry and the Energy Systems Analysis And Management Manual Task Force was formed to develop a revised and updated manual that addresses the variety of services which can be provided by the SMACNA contractor.

The intent of this manual is to provide the SMACNA contractor an overview of a variety of business opportunities, allowing the contractor to select those which might provide the greatest return on investment consistent with market forces in the local area. Topics presented in this manual include:

- Energy Conservation Management
- Air Systems
- Domestic Water Systems
- Electrical Systems
- HVAC System Maintenance And IAQ
- The Energy Audit
- Energy Management Maintenance And Monitoring
- Energy Estimating Procedures
- Economics Of Energy Reduction Projects
- CFC Refrigerant Regulation
- Energy Recovery Systems
- Evaporative Air Coolers
- Alternative Energy Systems
- Hydronic Recovery Systems
- Energy Recovery System Investment Analysis
- Energy Conservation Measures
- Legacy Systems
- Fundamentals Of Energy Transfer

It is not the intent of this manual to present these topics in depth. It is intended that manual present a general description of each topic with guidelines explaining the general knowledge or expertise required to pursue the various options. Once a reader determines that they wish to pursue a topic in more depth, they are directed to other SMACNA manuals or publications.

SMACNA wishes to thank the efforts and funding of the National Energy Management Institute in assisting in the development of the first edition, and their contribution towards the second edition for the industry. SMACNA also thanks the SMACNA contractors who, as members of the Energy Systems Analysis And Management Manual Task Force, volunteered their time and effort to the development of this manual. SMACNA appreciates their dedication and willingness to share their knowledge and experience.

SHEET METAL AND AIR CONDITIONING CONTRACTORS'
NATIONAL ASSOCIATION, INC.



ENERGY SYSTEMS ANALYSIS AND MANAGEMENT TASK FORCE

Steve Perrone, Chairman
Harrington Bros.
Stoughton, MA

Philip Chiarappa
Best Commercial Energy Services
Akron, OH

Matt Jesson
Systems Management & Balancing
Waukee, IA

Darrin Putnam
Jack's Mechanical Solutions, Inc.
Albuquerque, NM

Allison Fee
SMACNA, Inc.
Chantilly, VA

Mark Terzigni
SMACNA, Inc.
Chantilly, VA

Shawn OHara
SMACNA, Inc.
Chantilly, VA

FORMER COMMITTEE MEMBERS AND OTHER CONTRIBUTORS

National Energy Management Institute
Alexandria, VA

John Wimer, Chairman
G.R. Sponaugle & Sons, Inc.
Harrisburg, PA

Lou Lagomarsino
J.B. Rodgers Performance Contracting
Phoenix, AZ

John Jamsion
Construction Mechanical Systems
Grapevine, TX

IBS, Inc.
Bowie, MD

Kenneth Johnson
Albers Sheetmetal & Ventilating
West St. Paul, MN

Kirk Jackson
Jackson & Blanc
San Diego, CA

Eli Howard
SMACNA, Inc.
Chantilly, VA

NOTICE TO USERS OF THIS PUBLICATION

1. DISCLAIMER OF WARRANTIES

a) The Sheet Metal and Air Conditioning Contractors' National Association ("SMACNA") provides its product for informational purposes.

b) The product contains "Data" which is believed by SMACNA to be accurate and correct but the data, including all information, ideas and expressions therein, is provided strictly "AS IS," with all faults. SMACNA makes no warranty either express or implied regarding the Data and SMACNA EXPRESSLY DISCLAIMS ANY IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR PARTICULAR PURPOSE.

c) By using the data contained in the product user accepts the Data "AS IS" and assumes all risk of loss, harm or injury that may result from its use. User acknowledges that the Data is complex, subject to faults and requires verification by competent professionals, and that modification of parts of the Data by user may impact the results or other parts of the Data.

d) IN NO EVENT SHALL SMACNA BE LIABLE TO USER, OR ANY OTHER PERSON, FOR ANY INDIRECT, SPECIAL OR CONSEQUENTIAL DAMAGES ARISING, DIRECTLY OR INDIRECTLY, OUT OF OR RELATED TO USER'S USE OF SMACNA'S PRODUCT OR MODIFICATION OF DATA THEREIN. This limitation of liability applies even if SMACNA has been advised of the possibility of such damages. IN NO EVENT SHALL SMACNA'S LIABILITY EXCEED THE AMOUNT PAID BY USER FOR ACCESS TO SMACNA'S PRODUCT OR \$1,000.00, WHICHEVER IS GREATER, REGARDLESS OF LEGAL THEORY.

e) User by its use of SMACNA's product acknowledges and accepts the foregoing limitation of liability and disclaimer of warranty and agrees to indemnify and hold harmless SMACNA from and against all injuries, claims, loss or damage arising, directly or indirectly, out of user's access to or use of SMACNA's product or the Data contained therein.

2. ACCEPTANCE

This document or publication is prepared for voluntary acceptance and use within the limitations of application defined herein, and otherwise as those adopting it or applying it deem appropriate. It is not a safety standard. Its application for a specific project is contingent on a designer or other authority defining a specific use. SMACNA has no power or authority to police or enforce compliance with the contents of this document or publication and it has no role in any representations by other parties that specific components are, in fact, in compliance with it.

3. AMENDMENTS

The Association may, from time to time, issue formal interpretations or interim amendments, which can be of significance between successive editions.

4. PROPRIETARY PRODUCTS

SMACNA encourages technological development in the interest of improving the industry for the public benefit. SMACNA does not, however, endorse individual manufacturers or products.

5. FORMAL INTERPRETATION

a) A formal interpretation of the literal text herein or the intent of the technical committee or task force associated with the document or publication is obtainable only on the basis of written petition, addressed to the Technical Resources Department and sent to the Association's national office in Chantilly, Virginia. In the event that the petitioner has a substantive disagreement with the interpretation, an appeal may be filed with the Technical Resources Committee,



which has technical oversight responsibility. The request must pertain to a specifically identified portion of the document that does not involve published text which provides the requested information. In considering such requests, the Association will not review or judge products or components as being in compliance with the document or publication. Oral and written interpretations otherwise obtained from anyone affiliated with the Association are unofficial. This procedure does not prevent any committee or task force chairman, member of the committee or task force, or staff liaison from expressing an opinion on a provision within the document, provided that such person clearly states that the opinion is personal and does not represent an official act of the Association in any way, and it should not be relied on as such. The Board of Directors of SMACNA shall have final authority for interpretation of this standard with such rules or procedures as they may adopt for processing same.

b) SMACNA disclaims any liability for any personal injury, property damage, or other damage of any nature whatsoever, whether special, indirect, consequential or compensatory, direct or indirectly resulting from the publication, use of, or reliance upon this document. SMACNA makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

6. APPLICATION

a) Any standards contained in this publication were developed using reliable engineering principles and research plus consultation with, and information obtained from, manufacturers, users, testing laboratories, and others having specialized experience. They are subject to revision as further experience and investigation may show is necessary or desirable. Construction and products which comply with these Standards will not necessarily be acceptable if, when examined and tested, they are found to have other features which impair the result contemplated by these requirements. The Sheet Metal and Air Conditioning Contractors' National Association and other contributors assume no responsibility and accept no liability for the application of the principles or techniques contained in this publication. Authorities considering adoption of any standards contained herein should review all federal, state, local, and contract regulations applicable to specific installations.

b) In issuing and making this document available, SMACNA is not undertaking to render professional or other services for or on behalf of any person or entity. SMACNA is not undertaking to perform any duty owed to any person or entity to someone else. Any person or organization using this document should rely on his, her or its own judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstance.

7. REPRINT PERMISSION

Non-exclusive, royalty-free permission is granted to government and private sector specifying authorities to reproduce only any construction details found herein in their specifications and contract drawings prepared for receipt of bids on new construction and renovation work within the United States and its territories, provided that the material copied is unaltered in substance and that the reproducer assumes all liability for the specific application, including errors in reproduction.

8. THE SMACNA LOGO

The SMACNA logo is registered as a membership identification mark. The Association prescribes acceptable use of the logo and expressly forbids the use of it to represent anything other than possession of membership. Possession of membership and use of the logo in no way constitutes or reflects SMACNA approval of any product, method, or component. Furthermore, compliance of any such item with standards published or recognized by SMACNA is not indicated by presence of the logo.

TABLE OF CONTENTS

FOREWORD	iii
ENERGY SYSTEMS ANALYSIS AND MANAGEMENT TASK FORCE	iv
NOTICE TO USERS OF THIS PUBLICATION	v
TABLE OF CONTENTS	vii
CHAPTER 1 ENERGY CONSERVATION MANAGEMENT	
1.1 ENERGY USE INFLUENCE FACTORS	1.1
1.2 BUILDING ENVELOPE	1.1
1.3 HUMAN COMFORT NEEDS	1.4
1.4 ENERGY MANAGEMENT (OPERATION)	1.4
1.5 INITIAL COST VERSUS OPERATING COSTS	1.5
1.6 EVALUATION	1.5
1.7 EXISTING BUILDINGS	1.6
1.8 ENERGY CONSERVATION CHECKLIST	1.7
1.9 SYSTEM MODIFICATIONS	1.8
1.10 STRUCTURE MODIFICATIONS	1.8
1.11 NEW BUILDINGS	1.9
1.12 THE DESIGN PROCESS	1.9
1.13 ENERGY EFFICIENT DESIGN	1.9
1.14 HVAC SYSTEM EVALUATION	1.10
CHAPTER 2 AIR SYSTEMS	
2.1 AIR SYSTEM CLASSIFICATIONS	2.1
2.2 AIR SYSTEM BENEFITS	2.1
2.3 AIR SYSTEM DESIGN BASICS	2.1
2.4 DUCT SYSTEM AIRFLOW	2.2
2.5 TYPES OF AIR SYSTEMS	2.3
2.6 HVAC SYSTEM VS BUILDING TYPE	2.9
2.7 ENERGY SAVING OPPORTUNITIES	2.10
CHAPTER 3 DOMESTIC WATER SYSTEMS	
3.1 ENERGY ANALYSIS	3.1
3.2 REDUCED WATER TEMPERATURES	3.2
3.3 HOT WATER USAGE	3.2
3.4 SYSTEM THERMAL LOSSES	3.4
3.5 SOLAR DOMESTIC HOT WATER SYSTEMS	3.4
CHAPTER 4 ELECTRICAL SYSTEMS	
4.1 LIGHTING	4.1
4.2 POWER	4.6
4.3 ELECTRICAL EQUIPMENT	4.8
CHAPTER 5 HVAC SYSTEM MAINTENANCE AND IAQ	
5.1 IAQ	5.1
5.2 MAINTENANCE	5.2



CHAPTER 6	THE ENERGY AUDIT	
6.1	OBTAINING INITIAL COOPERATION	6.1
6.2	ESTABLISHING AN ENERGY CONSERVATION GOAL	6.1
6.3	THE BUILDING SURVEY	6.2
6.4	THE DATABASE	6.5
6.5	USING THE AUDIT DATA	6.7
CHAPTER 7	ENERGY MANAGEMENT MAINTENANCE AND MONITORING	
7.1	ENERGY CONSERVATION MONITORING	7.1
7.2	VERIFICATION PROCEDURES	7.1
CHAPTER 8	ENERGY ESTIMATING PROCEDURES	
8.1	ENERGY ESTIMATING	8.1
8.2	ANALYSIS OF ENERGY CONSERVATION EXAMPLE	8.6
CHAPTER 9	ECONOMICS OF ENERGY REDUCTION PROJECTS	
9.1	GENERAL	9.1
9.2	COMPUTING FUEL SAVINGS	9.2
9.3	MAKING A SIMPLE CAPITAL INVESTMENT ANALYSIS	9.7
9.4	LIFE-CYCLE COSTING	9.10
CHAPTER 10	CFC REFRIGERANT REGULATION	
10.1	BACKGROUND	10.1
10.2	CONCLUSIONS	10.4
CHAPTER 11	ENERGY RECOVERY SYSTEMS	
11.1	COMFORT-TO-COMFORT	11.1
11.2	PROCESS-TO-COMFORT	11.2
11.3	PROCESS-TO-PROCESS	11.2
11.4	ENERGY RECOVERY EQUIPMENT IN GENERAL	11.3
11.5	EXCHANGER CONFIGURATIONS AND DESIGN	11.4
11.6	TYPES OF EXCHANGERS	11.5
11.7	EXCHANGER CHARACTERISTICS	11.19
11.8	EXCHANGER RATINGS AND STANDARDS	11.20
11.9	MECHANICS OF HEAT FLOW	11.22
11.10	EFFECTIVENESS	11.23
11.11	EXCHANGER CAPACITY REDUCTION	11.23
11.12	THERMAL TRANSFER FLUIDS	11.24
11.13	HEAT TRANSFER MEDIA EVALUATION	11.25
11.14	EQUIPMENT DESIGN	11.25
CHAPTER 12	EVAPORATIVE AIR COOLERS	
12.1	DIRECT EVAPORATIVE COOLING	12.1
12.2	INDIRECT EVAPORATIVE COOLING	12.1
12.3	INDIRECT/DIRECT EVAPORATIVE COOLING SYSTEMS	12.3
CHAPTER 13	ALTERNATIVE ENERGY SYSTEMS	
13.1	SOLAR ENERGY SYSTEMS	13.1
13.2	HYBRID SYSTEMS	13.4
13.3	THERMAL STORAGE SYSTEMS	13.4
13.4	GEO THERMAL	13.6



CHAPTER 14 HYDRONIC RECOVERY SYSTEMS

14.1 TWO-PIPE ENERGY RECOVERY SYSTEMS..... 14.1
14.2 CONDENSATE HEAT RECOVERY 14.1
14.3 WASTE WATER HEAT RECOVERY..... 14.2
14.4 COGENERATION SYSTEMS..... 14.2

CHAPTER 15 ENERGY RECOVERY SYSTEM INVESTMENT ANALYSIS

15.1 PARTIAL METHODS OF EVALUATION ENERGY RECOVERY SYSTEM
INVESTMENT ANALYSIS 15.1
15.2 COMPREHENSIVE METHODS FOR EVALUATING INVESTMENT
ALTERNATIVES 15.4
15.3 SPECIAL FACTORS TO CONSIDER IN INVESTMENT ANALYSIS 15.10
15.4 APPLICATION OF EVALUATION METHODS TO DIFFERENT
KINDS OF DECISION 15.13
15.5 SUMMARY 15.15

CHAPTER 16 ENERGY CONSERVATION MEASURES

16.1 INTRODUCTION 16.1
16.2 OPERATIONAL MEASURES 16.1
16.3 ENERGY CONSERVATION CHECKLIST 16.1
16.4 SYSTEM MODIFICATIONS 16.2
16.5 STRUCTURE MODIFICATIONS 16.3
16.6 ENERGY EFFICIENT DESIGN 16.3

CHAPTER 17 LEGACY SYSTEMS

17.1 LEGACY AIR SYSTEMS 17.1
17.2 LEGACY HYDRONIC RECOVERY SYSTEMS 17.3

CHAPTER 18 FUNDAMENTALS OF ENERGY TRANSFER

18.1 HEAT FLOW..... 18.1
18.2 PSYCHROMETRIC CHARTS 18.6
18.3 USE OF THE PSYCHROMETRIC CHART 18.7
18.4 AIR MIXTURE CONDITION CHANGES 18.12
18.5 OTHER CHARTS 18.21



TABLES

Table 1–1	Factors Influencing Mechanical/Electrical System Load/Energy	1.2
Table 1–2	Building Envelope Costs as a Percentage of Total Building Costs	1.3
Table 1–2	Monthly Building or Plant Utility Usage.	1.6
Table 3–1	Domestic Hot Water Usage	3.1
Table 3–2	Tank Loss	3.2
Table 4–1	Suggested Lighting Levels	4.2
Table 4–2	Relative Efficiency of Bulb Types	4.9
Table 4–3	Capacitor Correction for Power Factor	4.11
Table 6–1	Detailed Energy Audit Report Outline.	6.4
Table 6–2	Audit Equipment Carried by the Retrofit Team	6.5
Table 6–3	Equipment Available to the Retrofit Team.	6.6
Table 8–1	Average Monthly and Yearly Degree Days for Cities in the United States and Canada (Base 65°F) (Sample Table)	8.1
Table 8–2	Correction Factors for Outdoor Design Temperatures	8.2
Table 8–3	Unit Fuel Consumption Constants (Based on 0°F Outdoor Temperature, 70°F Indoor Temperature).	8.2
Table 8–4	Required [Energy Savings/Total Cost] Ratio for 5-year Payback Period.	8.8
Table 9–1	Annual Fuel Utilization Efficiency	9.3
Table 9–2a	Heating Value of Common Fuels (U.S. Units).	9.3
Table 9–2b	Heating Value of Common Fuels (Metric Units)	9.3
Table 9–3	Unit Fuel Consumption Constants (Based on 0°F Outdoor Temperature, 70°F Indoor Temperature).	9.10
Table 9–4	Capital Recovery Factors	9.11
Table 10–1	Comparison of the Montreal Protocol and United States Phaseout Schedules	10.1
Table 10–2	Common Refrigerants Used Today.	10.3
Table 11–3	Frost Threshold Temperature, T1, for Various Exhaust Air Conditions	11.9
Table 11–1	Characteristics of Energy Recovery Devices	11.20
Table 11–2	Comparison of Air-to-Air Energy Recovery Systems	11.21
Table 13–1	Air Solar Heating Systems	13.2
Table 13–2	Liquid Solar Heating Systems	13.3
Table 15–1	Potential Costs to Consider in Investing in Energy Recovery Systems	15.1
Table 15–2	An Illustration That Payback Analysis Does Not Take Into Account Cash Flows Beyond the Payback Period	15.3



Table 15-3	An Illustration That the Undiscounted Payback Method Can Result in Inaccurate Methods	15.3
Table 15-4	Discounting Equations	15.5
Table 15-5	Illustrative Discounting of Representative Costs and Benefits	15.6
Table 15-6	Illustration of Net Present Value Method	15.8
Table 15-7	Kinds of Investment Decision Problems	15.14
Table 15-8	Net Benefits and Benefit/Cost Ratio Rankings for a Set of Independence Projects	15.15
Table 15-9	6% Compound Interest Factors	15.16
Table 15-10	8% Compound Interest Factors	15.17
Table 15-11	10% Compound Interest Factors	15.18
Table 15-12	12% Compound Interest Factors	15.19
Table 15-13	15% Compound Interest Factors	15.20
Table 18-1	Thermodynamic Properties of Moist Air Standard Atmospheric Pressure (14.696 psi)	18.13
Table 18-2	Thermodynamic Properties of Moist Air (Metric) Standard Atmospheric Pressure (101.325 kPa)	18.15



FIGURES

Figure 1–1	Major Components of Building Envelope	1.3
Figure 2–1	Constant Volume Single-Zone System	2.4
Figure 2–2	Constant Volume Reheat System.	2.4
Figure 2–3	VAV System	2.5
Figure 2–4	VAV with Reheat System	2.6
Figure 2–5	VAV with Fan Powered Terminal Units	2.7
Figure 4–1	Power Factor Relationships	4.8
Figure 4–2	Totally Enclosed, Fan-Cooled Motor Replacement.	4.10
Figure 5–1	Cooling Tower.	5.2
Figure 5–2	Cooling Tower Intake Louvers.	5.3
Figure 5–4	HVAC System.	5.3
Figure 5–5	Cooling Coil/Fan Section	5.4
Figure 7–1	Electric Power Consumption.	7.2
Figure 11–1	Comfort-to-Comfort Sensible	11.1
Figure 11–2	Comfort-to-Comfort Total Heat (Enthalpy) Transfer.	11.1
Figure 11–3	Process-to-Comfort Energy Recovery System.	11.3
Figure 11–4	Process-to-Process Energy Recovery System	11.3
Figure 11–5	Counterflow Airstreams	11.4
Figure 11–6	Parallel-Flow Airstreams.	11.4
Figure 11–7	Cross-Flow Airstreams	11.4
Figure 11–8	Run-Around Coil Exchangers (Closed Heat Recovery Loop).	11.5
Figure 11–9	Plate Type Heat Exchanger	11.6
Figure 11–10	Pressure Drop vs. Flow (Fixed Plate Recovery Unit)	11.7
Figure 11–11	Plate Exchanger with Bypass Damper	11.9
Figure 11–12	Rotary Wheel Exchanger	11.9
Figure 11–13	Rotary Wheel Purge Section (Directionally Oriented Media)	11.11
Figure 11–14	Representative Pressure Drops for Rotary Wheel Exchangers	11.11
Figure 11–15	Typical Rotary Wheel	11.12
Figure 11–16	Effectiveness of Unequal Airflows	11.12
Figure 11–17	Bypass Dampers	11.13
Figure 11–18	Condensation and Frosting.	11.13

Figure 11–19	Face-and-Bypass Dampers	11.14
Figure 11–20	Variable Speed Drive	11.14
Figure 11–21	Run-Around Coil Exchanger (Closed Heat Recovery Loop).	11.15
Figure 11–22	Run-Around Coil System with Expansion Tank	11.16
Figure 12–1	Evaporative Cooler	12.2
Figure 12–2	Indirect Evaporative Cooling Heat Exchanger	12.2
Figure 13–1	Roof Monitor as a Solar Collector (Duct and Fan Circulates Trapped Hot Air Back to Floor Level)	13.2
Figure 13–2	Solar Heating and Cooling System Schematic.	13.2
Figure 13–3	Flat Plate Solar Collector (Air)	13.2
Figure 13–4	Air Solar Heating System	13.3
Figure 13–5	Solar Assisted Heat Pump Schematic	13.3
Figure 13–6	Integrated Storage System Schematic	13.6
Figure 14–1	Two-Pipe Energy Recovery System	14.2
Figure 14–2	Compressor Heat Recovery	14.2
Figure 14–3	Schematic of Laundry and Kitchen Hot Water Heat Recovery System	14.3
Figure 14–4	Cogeneration System Schematic	14.4
Figure 17–1	Single-Fan Dual Duct Low Velocity System	17.1
Figure 17–2	Multi-Zone System	17.2
Figure 17–3	Four-Pipe Energy Recovery System	17.5
Figure 18-1	Conductivity Defined for a Homogeneous Material	18.2
Figure 18-2	Conductance Defined for a Nonhomogeneous Material.	18.2
Figure 18-3	Heat Flow and Thermal Resistance	18.3
Figure 18-4	Heat Transfer Low Patterns.	18.4
Figure 18-5	Heat Transfer Curves	18.4
Figure 18-6	Heat Transfer Relationship	18.5
Figure 18-7	Sample Psychrometric Chart (U.S. Units).	18.9
Figure 18-8	Psychrometric Chart — Typical Condition Points (U.S. Units)	18.10
Figure 18-9	Psychrometric Chart — Typical Condition Points (U.S. Units)	18.10
Figure 18-10	Psychrometric Chart – Typical Condition Points (Si Units)	18.11
Figure 18-11	Enthalpy Change	18.14
Figure 18-12	Sensible Heating and Cooling	18.16



Figure 18-13	Humidification and Dehumidification	18.16
Figure 18-14	Common Processes Shown on Psychrometric Chart.	18.17
Figure 18-15	Cooling and Dehumidification.	18.17
Figure 18-16	Heating and Humidification.	18.18
Figure 18-17	Total Heat Content Change	18.18
Figure 18-18	Mixing Airstream on the Psychrometric Chart	18.21



CHAPTER 1

**ENERGY CONSERVATION
MANAGEMENT**

Many of today's buildings include complex systems such as the following: security, stairwell pressurization, smoke purge, fire alarm, emergency lighting, building management system (BMS), building automation system (BAS), hot water heating piping, chilled water piping, domestic water piping, gas piping, exhaust air, emergency computer UPS, and computerized lighting control.

These systems have not only stretched the limits of the traditional facility maintenance department to keep them operating, but have greatly increased facility energy usage. When these complex systems are not maintained or controlled properly, the energy consumption can increase dramatically.

The accounting department in most facilities is usually responsible for receiving and paying all utility bills. Since most building owners do not consider utilities as a controllable cost, these bills are usually processed each month without any management review. The building maintenance or facility management department is usually judged by their ability in responding to trouble calls and keeping the heating and cooling systems operating, not in their ability to reduce energy usage. There are relatively few facilities which tie these functions together with the management and feedback overview needed to manage today's increasing utility costs.

When there is no direct accounting relationship between HVAC system maintenance and utility usage, there is no incentive to reduce utility costs. Maintenance staffing and supplies will continue to be cut to save costs as long as building managers do not have utility accounting controls that show the much higher utility costs that result from this short-sighted thinking.

In order to take control of utility costs, the energy relationship of the building systems must be understood. Understanding how the systems were intended to work will allow the creation of an energy and utility cost reduction plan. By using the energy auditing techniques in this text, you will learn how to identify the most cost effective system renovations to make and their relative priority. You will also learn how to set up the utility accounting procedures required to monitor the results of your new energy conservation program and justify future increased maintenance or renovation budget requests.

1.1 ENERGY USE INFLUENCE FACTORS

Nationwide, the systems that consume the most energy in order of decreasing magnitude are:

- Heating and Ventilating
- Lighting
- Air Conditioning
- Equipment and Process
- Domestic Hot Water

Requirements for the HVAC and electrical systems are controlled for the most part by building features listed in Table 1-1. The relative magnitude of each influence factor is suggested. In most cases the higher the magnitude, the greater the potential is for energy conservation.

1.2 BUILDING ENVELOPE

The building envelope is comprised of the roof, outside doors and windows, skylights, exterior walls, slab and all envelope joints. The building envelope protects the occupants from the outside elements and provides a protected thermal environment. It has a direct and significant impact on the building's energy use, and therefore, building energy codes have specific requirements for critical envelope components. The effectiveness of the building envelope depends on materials chosen, fenestration, installation, and environment and building purpose. See Figure 1-1 for the major components comprising the building envelope.

The building envelope is a significant portion of the building and building costs. See Table 1-2 for typical envelope costs as a percentage of the total building cost.

In regard to thermal losses through the building envelope, the performance depends on three variables: the area, the temperature difference between the inside and outside temperatures, and the material. The material properties dictate how easily heat transfer takes place and is quantified by the thermal conductivity, U . Equation 1-1 is used to calculate the thermal losses through the building envelope.

$$Q = U \times A \times \Delta T = U \times A \times (T_i - T_o) \quad \text{Equation 1-1}$$

Where:

- U = thermal conductivity = $1/R$
- R = thermal resistance
- A = area of envelope component
- T_i = temperature inside
- T_o = temperature outside.

