

ANSI/AMCA Standard 500-L-12 (Rev. 2015)

Laboratory Methods of Testing Louvers for Rating

An American National Standard
Approved by ANSI on Dec. 3, 2015



**AIR MOVEMENT AND CONTROL
ASSOCIATION INTERNATIONAL INC.**

The International Authority on Air System Components

ANSI/AMCA Standard 500-L-12 (Rev. 2015)

Laboratory Methods of Testing Louvers for Rating



Air Movement and Control Association International
30 W. University Drive
Arlington Heights, Illinois
60004

AMCA Publications

Authority	AMCA Standard 500-L (Rev. 2015) was adopted by the membership of the Air Movement and Control Association International Inc. on Oct. 28, 2015. It was approved by the American National Standards Institute on Dec.3, 2015.
Copyright	© 2007 by Air Movement and Control Association International Inc. All rights reserved. Reproduction or translation of any part of this work beyond that permitted by Sections 107 and 108 of the United States Copyright Act without the permission of the copyright owner is unlawful. Requests for permission or further information should be addressed to the executive director, Air Movement and Control Association International Inc. at 30 West University Drive, Arlington Heights, IL 60004-1893 U.S.
Objections	Air Movement and Control Association International Inc. will consider and take action upon all written complaints regarding its standards, certification programs or interpretations thereof. For information on procedures for submitting and handling complaints, write to Air Movement and Control Association International 30 West University Drive Arlington Heights, IL 60004-1893 U.S.A. AMCA International Incorporated European AMCA Avenue des Arts, numéro 46 à Bruxelles (1000 Bruxelles) Asia AMCA Sdn Bhd No. 7, Jalan SiLC 1/6, Kawasan Perindustrian SiLC Nusajaya, Mukim Jelutong, 79200 Nusajaya, Johor Malaysia
Disclaimer	AMCA uses its best efforts to produce publications for the benefit of the industry and the public in light of available information and accepted industry practices. However, AMCA does not guarantee, certify or assure the safety or performance of any products, components or systems tested, designed, installed or operated in accordance with AMCA publications or that any tests conducted under its publications will be non-hazardous or free from risk.

Review Committee

Tim Fleitz	Air Conditioning Products Co.
Jacob Carr	American Warming and Ventilating
Ken Moyer	Arrow United Industries
Jeffrey Blake	Construction Specialties Inc
Alex Talwar	Greenheck Fan Corp.
Mike Steele	Greenheck Fan Corp.
Dustin Gagner	Industrial Louvers
Mike Astourian	Metal Industries, Inc.
Stoil Pamoukov	Nailor Industries
Peter Blaha	PCI Industries Inc.
Matt Remington	Pottorff
Marc Hebert	Price Industries Ltd.
Matthew Joyce	Price Industries Ltd.
Dan Huber	Ruskin
Saad Ali	Ruskin Titus Gulf LLC
Dane Carey	TAMCO
Randal Geedey	PCI Industries Inc.
Chris Popoff	Western Ventilation Products Ltd
Tim Orris	AMCA Staff

Related AMCA Documents

Related Publications	AMCA Publication 501	<i>Application Manual for Louvers</i>
	AMCA Publication 511	<i>Certified Ratings Program – Product Rating Manual for Air Control Devices</i>
	AMCA Publication 512	<i>AMCA Listing Label Program</i>
Related Standards	ANSI/AMCA Standard 540	<i>Test Method for Louvers Impacted by Wind Borne Debris</i>
	ANSI/AMCA Standard 550	<i>Test Method for High Velocity Wind Driven Rain Resistant Louvers</i>

Contents

- 1. Purpose 1
- 2. Scope 1
- 3. Definitions/Units of Measurement/Symbols 1
 - 3.1 Definitions 1
 - 3.2 Units of measure 3
 - 3.3 Symbols and subscripts 3
- 4. Instruments and Methods of Measurement 3
 - 4.1 Accuracy [4] 3
 - 4.2 Pressure. 6
 - 4.3 Airflow rate 7
 - 4.4 Water flow rate 7
 - 4.5 Torque 8
 - 4.6 Air density 8
 - 4.7 Voltage 8
 - 4.8 Meters 8
 - 4.9 Pneumatic actuator supply air pressure. 8
 - 4.10 Pressure gauges 8
 - 4.11 Chronometers. 8
 - 4.12 Rain gauge. 8
- 5. Equipment and Setups. 9
 - 5.1 Setups 9
 - 5.2 Duct 9
 - 5.3 Chamber 9
 - 5.4 Variable supply and exhaust systems 10
 - 5.5 Wind driven rain simulation equipment 10
 - 5.6. Wind driven sand simulation equipment 11
- 6. Objective, Observations and Conduct of Test. 11
 - 6.1 Air performance-pressure drop test 11
 - 6.2 Airflow leakage rate 13
 - 6.3 Water penetration test 16
 - 6.4 Wind driven rain test 18
 - 6.5 Wind driven sand test 20
- 7. Calculations 22
 - 7.1 Calibration correction 22

7.2 Density and viscosity of air 22

7.3 Louver airflow rate at test conditions 22

7.4 Density correction 24

7.5 Air leakage/system leakage correction 25

Annex A Presentation of Air Performance Results for Rating Purposes (Informative) 54

Annex B Water Penetration Performance (Informative) 55

Annex C References (Informative). 56

Annex D Simulated Rain Spray Nozzles (Normative). 57

Annex E Water Eliminator Performance Test (Normative). 58

Annex F Wind Driven Rain Performance (Informative) 59

Annex G Core Area Measurements (Normative) 60

Annex H Grading of the Sand Used for the Wind Driven Sand Test (Normative) 61

Laboratory Methods of Testing Louvers for Rating

1. Purpose

The purpose of this standard is to establish uniform laboratory test methods for louvers. Characteristics to be determined include air leakage, pressure drop, water penetration, wind driven rain, wind driven sand and operational torque.

It is not the purpose of this standard to establish minimum or maximum performance ratings.

2. Scope

This standard may be used as a basis for testing louvers with air used as the test gas.

Tests conducted in accordance with the requirements of this standard are intended to demonstrate the performance of a louver and are not intended to determine acceptability level of performance. It is not the scope of this standard to indicate actual sequences of testing, nor is it in its scope to specify minimum or maximum criteria for testing.

The parties to a test for guarantee purposes may agree to exceptions to this standard in writing, prior to the test. However, only a test which does not violate any mandatory requirement of this standard shall be designated as a test conducted in accordance with this standard.

3. Definitions/Units of Measurement/Symbols

3.1 Definitions

3.1.1 Louver

A device comprised of multiple blades that, when mounted in an opening, permits the flow of air but inhibits the entrance of other elements.

3.1.1.1 Fixed blade louver

A louver in which the blades do not move.

3.1.1.2 Adjustable blade louver

A louver in which the blades may be operated either manually or by mechanical means.

3.1.1.3 Combination louver

A louver having both fixed and adjustable blades.

3.1.1.4 Sand louver

A louver comprised of multiple blades that, when mounted in an opening, permits the flow of air while minimizing the ingress of airborne sand particles.

3.1.2 Free area

The minimum area through which air can pass.

For horizontal blade louvers, free area is determined by multiplying the sum of the minimum distances between intermediate blades, top blade and head, and bottom blade and sill by the minimum distance between jambs.

For vertical blade louvers, free area is determined by multiplying the sum of the minimum distances between intermediate blades, left blade and left jamb, and right blade and right jamb by the minimum distance between head and sill.

The percent of free area is the free area thus calculated, divided by the gross area of the air control louver $\times 100$. See louver cross sections (Figure 1).

3.1.2.1 Free area velocity

The airflow through a louver divided by its free area.

3.1.3 Face area and core area

3.1.3.1 Face area

The total cross sectional area of a louver, duct or wall opening.

3.1.3.1.1 Face area velocity

The airflow through a louver divided by its face area.

3.1.3.2 Core area

The product of the minimum height, H , and minimum width, W , of the front opening in the louver assembly with the louver blades removed (see Annex G).

3.1.3.2.1 Louver calibration plate

A plate having an opening of the same geometric shape and dimensions as the core area of the test specimen.

3.1.3.2.2 Core area velocity

The airflow rate through the louver divided by the core area.

3.1.3.2.3 Core ventilation rate

The airflow rate through the core area of the louver.

3.1.4 Psychrometrics

3.1.4.1 Dry-bulb temperature (t_d)

The air temperature measured by a dry temperature sensor.

3.1.4.2 Wet-bulb temperature (t_w)

The temperature measured by a temperature sensor covered by a water-moistened wick and exposed to air in