

AMCA Publication 511-10 (Rev. 12-15)

**Certified Ratings Program
Product Rating Manual for
Air Control Devices**



**AIR MOVEMENT AND CONTROL
ASSOCIATION INTERNATIONAL, INC.**

The International Authority on Air System Components

AMCA Publication 511-10 (Rev. 12-15)

Certified Ratings Program Product Rating Manual for Air Control Devices



Air Movement and Control Association International
30 W. University Drive
Arlington Heights, Illinois
60004

AMCA Publications

Authority AMCA Publication 511-10 (Rev. 2015) was adopted by the membership of the Air Movement and Control Association International Inc. on December 29, 2015.

Copyright © 2007 by Air Movement and Control Association International Inc.

All rights reserved. Reproduction or translation of any part of this work beyond that permitted by Sections 107 and 108 of the United States Copyright Act without the permission of the copyright owner is unlawful. Requests for permission or further information should be addressed to the executive director, Air Movement and Control Association International Inc. at 30 West University Drive, Arlington Heights, IL 60004-1893 U.S.A.

Objections Air Movement and Control Association International Inc. will consider and take action upon all written complaints regarding its standards, certification programs, or interpretations thereof. For information on procedures for submitting and handling complaints, write to:

Air Movement and Control Association International
30 West University Drive
Arlington Heights, IL 60004-1893 U.S.A.

European AMCA
Avenue des Arts, numéro 46
à Bruxelles (1000 Bruxelles)

Asia AMCA Sdn Bhd
No. 7, Jalan SiLC 1/6,
Kawasan Perindustrian SiLC Nusajaya,
Mukim Jelutong, 79200 Nusajaya, Johor
Malaysia

Disclaimer AMCA uses its best efforts to produce publications for the benefit of the industry and the public in light of available information and accepted industry practices. However, AMCA does not guarantee, certify or assure the safety or performance of any products, components or systems tested, designed, installed or operated in accordance with AMCA publications or that any tests conducted under its publications will be non-hazardous or free from risk.

Review Committee

Marty Gissel Committee Chair	Greenheck Fan Corporation
Mike Steele	The Airolite Company LLC
Jacob Carr	American Warming and Ventilation
Jeff Blake	Construction Specialties Inc.
Bin Ngo	Daniel Mechanical
Eric Gohring	Mestek Inc.
Michael J. Bulzomi	Nailor Industries Inc.
Matt Remington	Potorff
Randal Geedey	Pottorff
Dan Huber	Ruskin Manufacturing Co.
Dane Carey	TAMCO Dampers
Jason Haley	Ventex Inc
Tim Orris	AMCA International

Related AMCA Documents

Related Publications	AMCA Publication 11	Certified Ratings Program Operating Manual
	AMCA Publication 111	Laboratory Accreditation Program
	AMCA Publication 512	AMCA Listing Label Program
Related Standards	ANSI/AMCA Standard 500-D	Laboratory Methods for Testing Dampers for Rating
	ANSI/AMCA Standard 500-L	Laboratory Methods for Testing Louvers for Rating
	ANSI/AMCA Standard 540	Test Method for Louvers Impacted by Wind Borne Debris
	ANSI/AMCA Standard 550	Test Method for High Velocity Wind Driven Rain Resistant Louvers

Contents

1. Purpose	1
2. Scope	1
3. Definitions and Symbols	1
3.1 Definitions	1
3.2 Symbols	2
4. Data Submittal Requirements	2
5. Required Catalog Statements	2
5.1 Licensed product statement	2
5.2 Licensed performance statement	2
5.3 Appurtenances statement	2
6. General Guidelines for Air Control Products	3
6.1 Manufacturer's responsibility	3
6.2 AMCA staff responsibility	3
6.3 Rating development	3
6.4 Aerodynamically similar products	3
6.5 Nameplated products	3
7. Check Test Tolerances and Required Tests	3
7.1 Licensee's duty	3
7.2 Tolerances	3
7.3 Required tests	4
8. Louver Air Performance Rating Requirements	5
8.1 Testing requirements	5
8.2 Calculated performance	5
8.3 Published ratings	5
9. Louver Wind Driven Rain Rating Requirements	7
9.1 Testing requirements	7
9.2 Calculated performance	7
9.3 Published ratings	7
10. Louver Wind Driven Sand Rating Requirements	8
10.1 Testing requirements	8
10.2 Calculated performance	8
10.3 Published ratings	8
11. Louver Water Penetration Rating Requirements	9
11.1 Testing requirements	9
11.2 Calculated performance	9
11.3 Published ratings	10

12. Acoustical Louver Sound Performance Rating Requirements	11
12.1 Testing requirements	11
12.2 Calculated performance	11
12.3 Published ratings	11
13. Adjustable Louver Air Leakage Rating Requirements	12
13.1 Testing requirements	12
13.2 Calculated performance	12
13.3 Published ratings	12
14. Damper Air Performance Rating Requirements	13
14.1 Testing requirements	13
14.2 Calculated performance	13
14.3 Published ratings	14
15. Volume Control Damper Air Leakage Rating Requirements	15
15.1 Testing requirements	15
15.2 Calculated performance	15
15.3 Published ratings	16
16. Ultra-Low-Leakage Damper Air Leakage Rating Requirements	17
16.1 Testing requirements	17
16.2 Calculated performance	17
16.3 Published ratings	17
17. Bubble-Tight Damper Air Leakage Rating Requirements	18
17.1 Testing requirements	18
17.2 Calculated performance	18
17.3 Published ratings	18
18. UL-Classified Damper Air Leakage Rating Requirements	19
18.1 Testing requirements	19
18.2 Calculated performance	19
18.3 Published ratings	19
19. Backdraft Damper Air Leakage Rating Requirements	20
19.1 Testing requirements	20
19.2 Calculated performance	20
19.3 Published ratings	20
20. Gravity Ventilator (Excluding Louver Penthouses) Air Performance Rating Requirements	21
20.1 Testing requirements	21
20.2 Calculated performance	21
20.3 Published ratings	21
21. Round Spiral Duct Air Leakage Rating Requirements	23

21.1 Testing requirements 23

21.2 Calculated performance. 23

21.3 Published ratings 23

22. Louver/Damper | Energy Efficiency Rating Requirements. 24

22.1 Testing requirements 24

22.2 Calculated performance. 24

22.3 Published ratings 24

23. Transverse Duct Connectors | Air Leakage Rating Requirements 25

23.1 Testing requirements 25

23.2 Calculated performance. 26

23.3 Published ratings 26

Annex A Electronic Catalogs (Normative). 27

Annex B Measurements (Normative). 29

Annex C Developing Air Control Product Catalogs (Informative) 32

Certified Ratings Program

Product Rating Manual for Air Control Devices

1. Purpose

AMCA Publication 511 dictates proper presentation of data and other required technical procedures for certification of air control devices under the AMCA Certified Ratings Program. This manual shall be used in conjunction with the current edition of AMCA Publication 11.

2. Scope

The products within the scope of this program are air control devices for use in general ventilation and air conditioning systems.

This program shall apply only to complete cataloged series of sizes. It shall not apply to individual sizes in a series, or part of a series of sizes, or to special units on which catalog ratings are not published.

The AMCA Certified Ratings seal shall be used only in connection with the specifically licensed device. The AMCA Seal shall be used only on complete units. The application of the AMCA seal to individual component parts, such as blades, frames, etc., is not permitted.

3. Definitions and Symbols

3.1 Definitions

All definitions found in AMCA Publication 11, as well as the definitions in this section, apply to this program.

3.1.1 Appurtenance

Appurtenance is any item in the air stream or on the inlet or discharge of the air control device that may affect the performance of the air control device.

An appurtenance shall be considered a part of the air control device if it is in place when the device is tested for performance rating and the effect of the appurtenance is included in the cataloged performance rating.

3.1.2 AMCA Certified Ratings Program

The Certified Ratings Program is a program for certifying a product's performance ratings, as defined in this document.

3.1.3 Performance rating(s)

Performance ratings are data generated from actual tested products used to derive the certified and published information.

3.1.4 Shall and should

The word *shall* indicates a mandatory requirement; the word *should* indicates an advisory statement.

3.1.5 Aerodynamically similar

Louver and damper designs are considered to be aerodynamically similar if the profiles of the components in the air stream are geometrically similar. The blades shall be in relative position to the frame and the center-to-center dimensions shall be the same. Frame, blade stops and blade profiles may have slight variances due to manufacturing methods. Blades must have the same streamline shape in that their leading and trailing edges shall be dimensionally equal. The overall angle or curvature of the blade must be the same. Slight deviations in material thickness shall not reduce the overall free area by more than 5% for dampers and 2.5% for louvers. Blade seals shall have the same profile, be of the same durometer and be secured to the blade in the same manner.

In addition to the requirements described above, louver or damper models claiming aerodynamic similarity for the purpose of certifying leakage performance or energy efficiency performance shall meet the following criteria:

- The frames and blades shall have a modulus of elasticity (E) greater than or equal to the originally licensed model.
- The blade action (i.e., whether the damper is parallel or opposed blade) shall be the same as the originally licensed model.
- The method used for interconnecting the damper or louver blades (i.e., the linkage) shall be the same as the originally licensed model.
- The jamb seal shall be the same as the originally licensed model.
- The blade axle bearing assemblies shall be the same as the originally licensed model.

3.1.6 Volume control damper

A volume control damper is a device which, when mounted to a duct or opening, is used to vary the volume of air through the duct or opening. It can be operated manually or mechanically and may have one or more blades.

For the purposes of this document, dampers meeting the definition of a backdraft damper or a UL-classified damper shall not be considered a volume control damper. Ultra-low-leakage dampers and bubble-tight dampers may be tested as volume control dampers.