

AMCA Publication 600-16

Application Manual for
Airflow Measurement Stations



**AIR MOVEMENT AND CONTROL
ASSOCIATION INTERNATIONAL, INC.**

The International Authority on Air System Components

AMCA Publication 600-16

Application Manual for Airflow Measurement Stations



Air Movement and Control Association International
30 W. University Drive
Arlington Heights, Illinois
60004

AMCA Publications

Authority	AMCA Publication 600 was approved by the membership of the Air Movement and Control Association International Inc. on March 4, 2016.
Copyright	© 2006 by Air Movement and Control Association International Inc. All rights reserved. Reproduction or translation of any part of this work beyond that permitted by Sections 107 and 108 of the United States Copyright Act without the permission of the copyright owner is unlawful. Requests for permission or further information should be addressed to the executive director, Air Movement and Control Association International Inc. at 30 West University Drive, Arlington Heights, IL 60004-1893 U.S.A.
Objections	Air Movement and Control Association International Inc. will consider and take action upon all written complaints regarding its standards, certification programs or interpretations thereof. For information on procedures for submitting and handling complaints, write to Air Movement and Control Association International 30 West University Drive Arlington Heights, IL 60004-1893 U.S.A. AMCA International, Incorporated c/o Federation of Environmental Trade Associations 2 Waltham Court, Milley Lane, Hare Hatch Reading, Berkshire, United Kingdom RG10 9TH
Disclaimer	AMCA uses its best efforts to produce standards for the benefit of the industry and the public in light of available information and accepted industry practices. However, AMCA does not guarantee, certify or assure the safety or performance of any products, components or systems tested, designed, installed or operated in accordance with AMCA standards or that any tests conducted under its standards will be non-hazardous or free from risk.

Review Committee

Paresh Davé	Air Monitor Corporation
Glenn Esser	Ruskin Company
Michael Khoury	Paragon Controls Inc.
Keith Foszcz	Paragon Controls Inc.
Armin Hauer	ebm-papst Inc.
Josiah Wiley	Ruskin Company
Tim Orris	AMCA International Staff

Related AMCA Documents

Related Publications	AMCA Publication 11	<i>Damper Application Manual for Heating/ Ventilating and Air Conditioning</i>
	AMCA Publication 611	<i>Certified Ratings Program – Product Rating Manual for Airflow Measurement Stations</i>
Related Standards	ANSI/AMCA Standard 610	<i>Laboratory Methods of Testing Airflow Measurement Stations for Performance Rating</i>

Contents

- 1. Purpose 1**
- 2. Scope 1**
- 3. Definitions 1**
 - 3.1 Airflow 1
 - 3.2 Airflow measurement station (AMS). 1
 - 3.3 Static pressure 1
 - 3.4 Total pressure. 1
 - 3.5 Airflow measurement station performance variables 1
- 4. Principles of Operation 1**
 - 4.1 Types of AMS devices 2
- 5. Applications 3**
- 6. Selection Criteria 4**
 - 6.1 Obstructions. 4
 - 6.2 Operational range 4
 - 6.3 Environmental suitability 4
 - 6.4 Maintenance access 4
- 7. Locating the AMS in the Air System 4**
- 8. Airflow Turndown Considerations 4**
- 9. Conditions of Air Being Measured: Temperature, Altitude, Static Pressure and Humidity. 4**
- 10. Materials of Construction 5**
- 11. Installed Performance Validation 5**

Application Manual for Airflow Measurement Stations

1. Purpose

This application guide is intended to assist designers and users with the proper application, performance considerations, selection and limitations of airflow measurement stations.

This publication provides information and important points to be considered when designing or specifying heating, ventilating and air conditioning (HVAC) and other applications in installations requiring an airflow measurement station (AMS) for use in temperatures from -30 °C to +120 °C (-20 °F to +250 °F), pressures to 250 Pa (10 in. wg) and velocities to 28 m/s (5500 fpm).

2. Scope

The purpose of this document is to help avoid problems associated with misapplied or incorrectly installed AMSs. Problems may include incorrect location, inappropriate measurement range, mismatched accompanying instrumentation and an AMS incompatible with intended application.

This guide provides an overview of permanently installed AMSs and their application. This publication does not address portable devices used to measure airflow in test-and-balance applications.

It is not the intent of this manual to be used for detailed specifications; rather it serves as a guide toward understanding the various types of AMSs available and items to be considered for their proper use.

3. Definitions

3.1 Airflow

A flow of air or an air current, specifically one that passes through a dimensionally defined plane.

3.2 Airflow measurement station (AMS)

A sensing device that is used to measure the airflow rate in a system or fan appurtenance. It may consist of a single sensor or an array of sensors in permanent position in the air system. It may be supplied as a probe to be inserted into a ductwork or supplied in a casing approximating the size of the air system in which it is installed or as an air intake louver.

3.3 Static pressure

That portion of the air pressure that exists by virtue of the degree of compression or expansion.

3.4 Total pressure

The air pressure that exists by virtue of the degree of compression and rate of motion. It is the algebraic sum of the velocity pressure and the static pressure at a point. Thus if the air is at rest, the total pressure will equal the static pressure.

3.5 Airflow measurement station performance variables

3.5.1 Tested AMS airflow rate (Q_{AMS})

The AMS reported airflow rate or measurement as calculated according to the manufacturer's instructions. This calculation is based upon the output (pressure, current or voltage) of the AMS.

3.5.2 AMS differential pressure

The observed differential pressure between the high pressure output and the low pressure output of a differential pressure type AMS.

3.5.3 AMS electronic output

The observed voltage or current output of an electronic output type AMS that correlates directly and proportionately to the velocity of airflow in a duct.

3.5.4 Test AMS face area (A_{FACE})

The total cross sectional area of a louver, duct, wall or AMS opening.

3.5.5 AMS free area (A_{FREE})

The minimum area through which air can pass.

4. Principles of Operation

Proper application requires knowledge of the various types of AMSs and their principles of operation.

The airflow sensing devices used in an AMS include but are not limited to pitot types, differential pressure types, thermal dispersions, vortex shedding airflow sensors, orifice plates, fan inlets or air measurement louvers. These devices are explained as follows: