

AMCA 211-13 (Rev. 10-16)

Certified Ratings Program Product Rating Manual for Fan Air Performance



Air Movement and Control Association International

AMCA Corporate Headquarters

30 W. University Drive, Arlington Heights, IL 60004-1893, USA
communications@amca.org ■ Ph: +1-847-394-0150 ■ www.amca.org

© 2016 Air Movement & Control Association International

AMCA Publication 211-13

(Rev. 10-16)

Certified Ratings Program

Product Rating Manual for Fan Air Performance



Air Movement and Control Association International
30 West University Drive
Arlington Heights, Illinois
60004

AMCA Publications

Authority	AMCA Publication 211-16 was adopted by the membership of the Air Movement and Control Association International Inc. on October 11, 2016.
Copyright	© 2013 by the Air Movement and Control Association International Inc. All rights reserved. Reproduction or translation of any part of this work beyond that permitted by Sections 107 and 108 of the United States Copyright Act without the permission of the copyright owner is unlawful. Requests for permission or further information should be addressed to the executive director, Air Movement and Control Association International Inc. at 30 West University Drive, Arlington Heights, IL 60004-1893 U.S.
Objections	The Air Movement and Control Association (AMCA) International Inc. will consider and take action upon all written complaints regarding its standards, certification programs or interpretations thereof. For information on procedures for submitting and handling complaints, write to AMCA International 30 West University Drive Arlington Heights, IL 60004-1893 U.S.A. European AMCA Avenue des Arts, numéro 46 à Bruxelles (1000 Bruxelles) Asia AMCA Sdn Bhd No. 7, Jalan SiLC 1/6, Kawasan Perindustrian SiLC Nusajaya, Mukim Jelutong, 79200 Nusajaya, Johor Malaysia
Disclaimer	AMCA uses its best efforts to produce publications for the benefit of the industry and the public in light of available information and accepted industry practices. However, AMCA does not guarantee, certify or assure the safety or performance of any products, components or systems tested, designed, installed or operated in accordance with AMCA publications or that any tests conducted under its publications will be non-hazardous or free from risk.

Review Committee

Thomas Gustafson	Hartzell Air Movement Committee Chair
John Cermak	Acme Engineering and Manufacturing Corporation
Abishek Jain	Air Flow PVT. LTD.
Tim Sutton	Carnam Ltd.
Franco	Cincotti Comefri USA Inc.
Armin Hauer	ebm-papst Inc.
Fernando Ruiz	Contreras Equipos Electromecanicos, S.A. de C.V.
Scott Kurszewski	Greenheck Fan Corporation
Kim Osborn	Governair LLC
Michael Brendel	Lau Industries Inc.
Keith Lins	M. K. Plastics Corporation
Hesham Morten Gabr	Multi-Wing
Andy Timm	New York Blower
Rad Ganesh	Twin City Fan
Yong Ning Chen	Zhejiang Yilida Ventilator Co. Ltd.
Florian Braun	Ziehl-Abegg Inc.
Joe Brooks	AMCA International
Tim Orris	AMCA International

Contents

1. Purpose and Scope	1
2. Normative References	1
3. Definitions	1
3.1 Appurtenance (accessory)	1
3.2 AMCA Certified Ratings Program air performance	1
3.3 Performance rating(s)	1
3.4 Shall and should	2
3.5 Constant speed	2
3.6 As-run speed	2
3.7 Fan efficiency grade (FEG)	2
4. Data Submittal Requirements	2
5. Drive Methods	2
6. Ducted Inlet Simulation	2
7. Catalog Requirements	3
7.1 Scope of certification	3
7.2 Statement required adjacent to the seal	3
7.3 Application statements	3
7.4 Noncertified efficiency, FEG and/or sound ratings	3
7.5 The AMCA Certified Ratings Program seals	3
8. Fan Performance Ratings	4
8.1 Manufacturer's responsibility	4
8.2 AMCA staff's responsibility	4
8.4 Catalog data	6
9. Rating Method Details	6
9.1 Rating method A/B/D: centrifugal, mixed flow, axial, propeller, power roof ventilator, energy recovery ventilator (constant speed rating method)	6
9.2 Rating method C/E: centrifugal, mixed flow, axial, propeller, power roof ventilator, energy recovery ventilator (as-run speed rating method)	7
9.3 Rating method F: centrifugal, mixed flow, axial, propeller, power roof ventilator, energy recovery ventilator	8
9.4 Rating method G: air curtains	9
9.5 Rating method H: jet tunnel fans	11
9.6 Rating method I: agricultural fans	11
9.7 Rating method J: positive pressure ventilators	12
9.8 Rating method K: circulating fans	12
9.9 Rating method L: induced flow fans	13
9.10 Rating method M: residential ventilating fans	14
9.11 Rating method N: large diameter ceiling fans	16
10. Check Tests	17
10.1 Centrifugal fans, mixed flow, axial fans, propeller fans, power roof ventilators, agricultural fans, positive pressure ventilators and energy recovery ventilators	17

10.2 Air curtains	21
10.3 Jet tunnel fans	22
10.4 Circulating fans	22
10.5 Induced flow fans.....	22
11. Product Rating Requirements for Centrifugal and Mixed Flow Fans	23
11.1 Product configuration.....	23
11.2 Test conditions	23
11.3 Test data submittal requirements	24
12. Product Rating Requirements for Axial Fans	24
12.1 Product configuration.....	24
12.2 Test conditions	25
12.3 Test data submittal requirements	25
12.4 Precertification check tests.....	25
13. Product Rating Requirements for Propeller Fans	25
13.1 Product configuration.....	25
13.2 Test conditions	26
13.3 Test data submittal requirements	26
14. Product Rating Requirements for Power Roof Ventilators.....	26
14.1 Product configurations.....	26
14.2 Test conditions	27
14.3 Test data submittal requirements	27
14.4 Exhaust/supply units.....	27
15. Product Rating Requirements for Jet Tunnel Fans.....	28
15.1 Test setups	28
15.2 Product configuration.....	28
15.3 Test conditions	28
15.4 Test data submittal requirements.....	28
16. Product Rating Requirements for Air Curtains.....	28
16.1 Conformance to standards.....	28
16.2 Product configuration.....	29
16.3 Test conditions	29
17. Product Rating Requirements for Agricultural Fans	30
17.1 Product configuration.....	30
17.2 Catalog photographs or illustrations	30
17.3 Test conditions	30
17.4 Test data submittal requirements	31
17.5 Alternate motors	31
18. Product Rating Requirements for Positive Pressure Ventilators	31
18.1 Test setups.....	31
18.2 Product configuration.....	31
18.3 Catalog photographs or illustrations	32
18.4 Test conditions	32

18.5 Test data submittal requirements	32
18.6 Alternate motors/engines	32
19. Product Rating Requirements for Energy Recovery Ventilators/Heat Recovery Ventilators	32
19.1 Definitions	32
19.2 Test conditions	33
19.3 Catalog requirements	33
20. Product Rating Requirements for Circulating Fans	34
20.1 Test setups	34
20.2 Product configuration or examples of installation	34
20.3 Test conditions	34
20.4 Test data submittal requirements	34
21. Product Rating Requirements for Induced Flow Fans	34
21.1 Basic conditions	34
21.2 Test setups	35
21.3 Electric power requirements	35
21.4 Test data submittal requirements	35
22. Product Rating Requirements for Ceiling Fans	35
22.1 Test setups	35
22.2 Product configuration or examples of installation	35
Annex A Dimensional Requirements (Normative)	36
A.1 General requirements	36
Annex B CRP Forms (Normative)	56
Annex C Electronic Catalogs (Normative)	61
C.1 Introduction	61
C.2 Scope	61
C.3 Allowable performance modifications	61
C.4 Required qualifying statements	62
C.5 Certification of electronic performance data	64
C.6 Version numbers	64
C.7 Identifying certified performance	64
C.8 AMCA directory listings	64
Annex D Guidelines for Development of Fan Performance Ratings (Informative)	65
D.1 Introduction	65
D.2 Similarity	65
D.3 Compressibility	65
D.4 Test fan sizes and test speeds	66
D.5 Power transmission losses	67
Annex E Reference Material (Informative)	69
Annex F Summary of Available Rating Methods (Informative)	70

Certified Ratings Program—Product Rating Manual for Fan Air Performance

1. Purpose and Scope

The purpose of this manual is to prescribe technical procedures to be used in connection with the AMCA Certified Ratings Program for fan air performance.

Products that can be licensed by AMCA to bear the AMCA certified ratings seal are those defined in ANSI/AMCA Standard 99, Section 0068; ISO 13349 and IEC 60335-2-80 and are within the product scope of AMCA International.

The program applies only to fans and is not applicable to their component parts such as fan impellers and housings.

2. Normative References

AMCA Publication 11, Certified Ratings Program Operating Manual
ANSI/AMCA Standard 99, Standards Handbook
AMCA Publication 111, Laboratory Accreditation Program
AMCA Publication 200, Air Systems
ANSI/AMCA Standard 205, Energy Efficiency Classification for Fans
ANSI/AMCA Standard 210, Laboratory Methods of Testing Fans for Certified Aerodynamic Performance
ANSI/AMCA Standard 220, Laboratory Methods of Testing Air Curtain Units for Aerodynamic Performance Rating
ANSI/AMCA Standard 230, Laboratory Methods of Testing Air Circulating Fans for Rating
ANSI/AMCA Standard 240, Laboratory Methods of Testing Positive Pressure Ventilators for Aerodynamic Performance Rating
ANSI/AMCA Standard 250, Laboratory Methods of Testing Jet Tunnel Fans for Performance
ANSI/AMCA Standard 260, Laboratory Methods of Testing Induced Flow Fans for Rating
AMCA Publication 311, Certified Ratings Program Product Rating Manual for Fan Sound Performance
ISO 5801, Industrial Fans — Performance Testing Using Standardized Airways
ISO 13350, Industrial Fans — Performance Testing of Jet Fans
Appendix U to Subpart B of Part 430 — Uniform Test Method for Measuring the Energy Consumption of Ceiling Fans, 10 CFR Part 430, Subpart B — Test Procedures (including amendments published in the Energy Conservation Program: Test Procedures for Ceiling Fans; Final Rule, 81 FR 48619, July 25, 2016)
IEC 62301, Ed. 2 2011-01, Household electrical appliances – Measurement of standby power

3. Definitions

All definitions in AMCA Publication 11, as well as the following, apply to this program.

3.1 Appurtenance (accessory)

Any item in or on the inlet or discharge airstream that affects the performance of the fan. An accessory/appurtenance is henceforth referred to as an appurtenance.

3.2 AMCA Certified Ratings Program air performance

A program for certifying a product's aerodynamic performance ratings, as defined in this document.

3.3 Performance rating(s)

A statement of the pressure performance and power versus airflow at a given speed at standard inlet air density or other specified density. Efficiency may also be included in the performance ratings at the option of the licensee. Power shall be