BS EN 60079-13:2017



BSI Standards Publication

Explosive atmospheres

Part 13: Equipment protection by pressurized room "p" and artificially ventilated room "v" (IEC 60079-13:2017)

bsi.

National foreword

This British Standard is the UK implementation of EN 60079-13:2017. It is identical to IEC 60079-13:2017. It supersedes BS EN 60079-13:2010, which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee EXL/31, Equipment for explosive atmospheres.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2017
Published by BSI Standards Limited 2017

ISBN 978 0 580 87832 9

ICS 29.260.20

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 November 2017.

Amendments/corrigenda issued since publication

Date	Text affected

EUROPEAN STANDARD

NORME EUROPÉENNE

EUROPÄISCHE NORM

EN 60079-13

October 2017

ICS 29.260.20

Supersedes EN 60079-13:2010

English Version

Explosive atmospheres - Part 13: Equipment protection by pressurized room "p" and artificially ventilated room "v" (IEC 60079-13:2017)

Atmosphères explosives - Partie 13: Protection du matériel par salle à surpression interne "p" et salle ventilée artificiellement "v" (IEC 60079-13:2017)

Explosionsgefährdete Bereiche - Teil 13: Schutz von Einrichtungen durch einen überdruckgekapselten Raum "p" und einen fremdbelüfteten Raum "v" (IEC 60079-13:2017)

This European Standard was approved by CENELEC on 2017-06-26. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

© 2017 CENELEC All rights of exploitation in any form and by any means reserved worldwide for CENELEC Members.

Ref. No. EN 60079-13:2017 E

European foreword

The text of document 31/1309/FDIS, future edition 2 of IEC 60079-13, prepared by IEC/TC 31 "Equipment for explosive atmospheres" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 60079-13:2017.

The following dates are fixed:

• latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement	(dop)	2018-04-06
• latest date by which the national standards conflicting with the document have to be withdrawn	(dow)	2020-10-06

This document supersedes EN 60079-13:2010.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 60079-13:2017 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60079-2	NOTE	Harmonized as EN 60079-2.
IEC 60079-14	NOTE	Harmonized as EN 60079-14.
IEC 60079-17	NOTE	Harmonized as EN 60079-17.
IEC 60529	NOTE	Harmonized as EN 60529.
IEC 61285	NOTE	Harmonized as EN 61285.
IEC 61508 Series	NOTE	Harmonized as EN 61508 Series.
IEC 61511 Series	NOTE	Harmonized as EN 61511 Series.

Annex ZA
(normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

Publication	Year	Title	EN/HD	Year
IEC 60050-426	-	International Electrotechnical Vocabulary - Part 426: Equipment for explosive atmospheres	-	-
IEC 60079-0	-	Explosive atmospheres - Part 0: Equipment - General requirements	EN 60079-0	-
IEC 60079-10-1	-	Explosive atmospheres - Part 10-1: Classification of areas - Explosive gas atmospheres	EN 60079-10-1	-
IEC 60079-29	Series	Explosive atmospheres - Part 29: Gas detectors	EN 60079-29	Series

This page deliberately left blank

CONTENTS

FOREWORD 5
INTRODUCTION 7
1 Scope 8
2 Normative references 10
3 Terms and definitions 11
4 Requirements for all rooms 13
4.1 General 13
4.2 Type and level of protection 13
4.2.1 Pressurization "p" 13
4.2.2 Artificial ventilation "v" 14
4.3 Construction 14
4.4 Mechanical strength 14
4.5 Penetrations and seals 14
4.6 Personnel access doors 14
4.7 Inlets and outlets 15
4.8 Ducts 15
4.9 Purging and cleaning 15
4.9.1 General 15
4.9.2 Gases – Purging 15
4.9.3 Enclosures within the room 16
4.10 Ignition prevention under system failure 16
5 Clean air supply 16
5.1 General 16
5.2 Source of clean air 16
5.3 Environmental and air temperature conditions 17
5.4 Heating, ventilation and air conditioning services 17
6 Requirements for pressurized rooms 17
6.1 General 17
6.1.1 Design 17
6.1.2 Source of clean air 17
6.1.3 Flow 17
6.1.4 Pressurization system 17
6.1.5 Preventing the explosive atmosphere from entering through an open door 18
6.1.6 Airlock 18
6.1.7 Outward air velocity through a door 18
6.1.8 Air consuming device 19
6.1.9 Action when pressurization system fails 19
6.1.10 Re-energizing the room 19
6.2 Purging of rooms 19
6.2.1 General 19
6.2.2 Sequence of operations of the purging safety devices 20
6.2.3 Dusts – Cleaning 20
6.3 Minimum safety provisions, safety devices and electrical disconnects 20
6.3.1 Safety devices 20
6.3.2 Safety devices based upon level of protection 21

6.3.3 Gas detectors 21
6.4 Verification for pressurized rooms 21
6.4.1 General 21
6.4.2 Tests 21
6.4.3 Overpressure test 22
6.4.4 Purging test 22
6.4.5 Minimum pressure differential test 22
6.4.6 Confirmation of the ratings of the safety devices 22
6.4.7 Verification of sequence of operation of the safety devices 22
7 Requirements for artificially ventilated rooms 22
7.1 General 22
7.1.1 Design 22
7.1.2 Source of clean air 22
7.1.3 Minimum flow rate 23
7.1.4 Ventilation system 23
7.1.5 Air consuming device 24
7.1.6 Safety actions when ventilation system fails 24
7.1.7 Energizing the artificially ventilated area 24
7.2 Purging of artificially ventilated rooms 25
7.2.1 General 25
7.2.2 Sequence of operations of the purging safety devices 25
7.3 Minimum safety provisions, safety devices and electrical disconnects 25
7.3.1 Safety devices 25
7.3.2 Safety devices based upon equipment protection level 25
7.3.3 Artificial ventilation protection 26
7.3.4 Gas detectors 26
7.4 Loss of artificial ventilation 26
7.5 Verification for artificially ventilated rooms 27
7.5.1 General 27
7.5.2 Tests 27
7.5.3 Purging test 27
7.5.4 Minimum ventilation flow rate test 27
7.5.5 Confirmation of the ratings of the safety devices 27
7.5.6 Verification of sequence of operation of the safety devices 27
7.5.7 Testing of ventilation system 28
8 Marking 28
8.1 General 28
8.2 Marking of pressurized rooms 28
8.3 Marking for artificially ventilated rooms 29
9 Instructions 30
9.1 General 30
9.2 Technical documentation for pressurized rooms 30
9.3 Technical documentation for artificially ventilated rooms 30
9.4 Technical documentation for rooms protected by pressurization and artificial ventilation combined 31
9.5 Modifications 31
Annex A (informative) Maintenance 32
A.1 Periodic verification 32
A.2 Modifications 32

Annex B (informative) Guidelines when pressurization or artificial ventilation is not immediately restored 33
Annex C (informative) Examples of applications and associated guidelines 34
C.1 Examples of applications 34
C.2 Guidelines for gas turbine enclosure/package 34
Bibliography 35

Table 1 – Exclusion of specific clauses or subclauses of IEC 60079-0 9
Table 2 – Safety devices for pressurized rooms 21
Table 3 – Safety actions for artificial ventilation failure 24
Table 4 – Required safety devices for artificial ventilation 26

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

EXPLOSIVE ATMOSPHERES –

Part 13: Equipment protection by pressurized room "p" and artificially ventilated room "v"

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60079-13 has been prepared by IEC technical committee 31: Equipment for explosive atmospheres

This second edition cancels and replaces the first edition published in 2010. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

a) modification of the title of this document to include artificially ventilated room "v" in addition to pressurized room "p";
b) addition of types of protection "pb", "pc", and "vc" and removal of types of protection "px", "py", "pz" and "pv";
c) definition of the differences between pressurization and artificial ventilation types of protection;

d) removal of protection of rooms with an inert gas or a flammable gas from the scope of this document;

e) addition of an informative annex to include examples of applications where types of protection pressurization or artificial ventilation or pressurization and artificial ventilation can be used and associated guidelines.

The text of this document is based on the following documents:

FDIS	Report on voting
31/1309/FDIS	31/1317/RVD

Full information on the voting for the approval of this document can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

This document is to be used in conjunction with the principles of hazardous area classification from IEC 60079-10-1 and artificial ventilation for the protection of analyser(s) houses from IEC 60079-16.

A list of all parts in the IEC 60079 series, published under the general title *Explosive atmospheres*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

INTRODUCTION

This part of IEC 60079 gives requirements for the design, construction, assessment, verification and marking of rooms used to protect internal equipment by pressurization or artificial ventilation or both as applicable when located in an explosive gas atmosphere or combustible dust atmosphere hazardous area with or without an internal source of a flammable gas or vapour. It also includes a room located in a non-hazardous area that has an internal source of release of a flammable gas or vapour.

This document deals with rooms that are partially constructed in a manufacturer’s facility and intended to have the final installation completed on-site, as well as rooms that are constructed completely on-site. Rooms partially constructed in a manufacturer’s facility may include third-party verification. For rooms built on-site, this document can be used by plant operators as a guide for assessment of those facilities.

This document represents a major technical revision of the requirements for equipment protection by pressurized room "p" and artificially ventilated room "v" and should be considered as introducing all new requirements.

EXPLOSIVE ATMOSPHERES –

Part 13: Equipment protection by pressurized room "p" and artificially ventilated room "v"

1 Scope

This part of IEC 60079 gives requirements for the design, construction, assessment, verification and marking of rooms used to protect internal equipment:

– located in a Zone 1 or Zone 2 or Zone 21 or Zone 22 explosive atmosphere (an area normally requiring an equipment protection level (EPL) Gb, Gc, Db or Dc) without an internal source of gas/vapour release and protected by pressurization;

– located in a Zone 2 explosive atmosphere (an area normally requiring EPL Gc) with or without an internal source of gas/vapour release and protected by artificial ventilation;

– located in a non-hazardous area, containing an internal source of gas/vapour release and protected by artificial ventilation;

– located in a Zone 1 or Zone 2 or Zone 21 or Zone 22 explosive atmosphere (an area normally requiring EPL Gb, Gc, Db or Dc), containing an internal source of gas/vapour release and protected by both pressurization and artificial ventilation.

The term "room" used in this document includes single rooms, multiple rooms, a complete building or a room contained within a building. A room is intended to facilitate the entry of personnel and includes inlet and outlet ducts. An acoustic hood and other like enclosures designed to permit the entry of personnel can be considered as a room.

This document also includes requirements related safety devices and controls necessary to ensure that artificial ventilation, purging and pressurization is established and maintained.

A room assembled or constructed on site, can be either on land or off-shore. The room is primarily intended for installation by an end-user but could be constructed and assessed at a manufacturer’s facility, where the final construction such as ducting can be completed on site.

Rooms can be located in an explosive gas atmosphere requiring EPL Gb or Gc, or a combustible dust atmosphere requiring EPL Db, or Dc.

This document does not specify the methods that may be required to ensure adequate air quality for personnel with regard to toxicity and temperature within the room. National or other regulations and requirements may exist to ensure the safety of personnel in this regard.

Protection of rooms by using an inert gas or a flammable gas is outside of the scope of this document. It is recognized that such applications are special cases, which in part may be addressed using the principles from IEC 60079-2, but in all probability will also be the subject of additional, stringent engineering standards, procedures and practices. Pressurized enclosures for equipment that are not intended to facilitate the entry of personnel are addressed in IEC 60079-2, and are not in the scope of this document.

NOTE Maintenance recommendations are contained in Annex A until they can be included in IEC 60079-17.

This document supplements and modifies the general requirements of IEC 60079-0, except exclusions as indicated in Table 1. Where a requirement of this document conflicts with a requirement of IEC 60079-0, the requirement of this document takes precedence.