BS EN IEC 60071-2:2018



BSI Standards Publication

Insulation co-ordination

Part 2: Application guidelines

bsi.

National foreword

This British Standard is the UK implementation of EN IEC 60071-2:2018. It is identical to IEC 60071-2:2018. It supersedes BS EN 60071-2:1997, which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee GEL/28, Electrical Insulation Co-ordination.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2018
Published by BSI Standards Limited 2018

ISBN 978 0 580 93673 9

ICS 29.080.30; 29.080.01

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 May 2018.

Amendments/corrigenda issued since publication

Date	Text affected

EUROPEAN STANDARD

NORME EUROPÉENNE

EUROPÄISCHE NORM

EN IEC 60071-2

May 2018

ICS 29.080

Supersedes EN 60071-2:1997

English Version

Insulation co-ordination - Part 2: Application guidelines (IEC 60071-2:2018)

Coordination de l'isolement - Partie 2: Lignes directrices en matière d'application (IEC 60071-2:2018)

Isolationskoordination - Teil 2: Anwendungsrichtlinie (IEC 60071-2:2018)

This European Standard was approved by CENELEC on 2018-04-20. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

© 2018 CENELEC All rights of exploitation in any form and by any means reserved worldwide for CENELEC Members.

European foreword

The text of document 28/255/FDIS, future edition 4 of IEC 60071-2, prepared by IEC/TC 28 "Insulation co-ordination" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 60071-2:2018.

The following dates are fixed:

• latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement	(dop)	2019-01-20
• latest date by which the national standards conflicting with the document have to be withdrawn	(dow)	2021-04-20

This document supersedes EN 60071-2:1997.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 60071-2:2018 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60099-4:2014	NOTE	Harmonized as EN 60099-2014 (not modified).
IEC 60099-5	NOTE	Harmonized as EN IEC 60099-5.
IEC 60099-8	NOTE	Harmonized as EN IEC 60099-8.
IEC 60507	NOTE	Harmonized as EN 60507.
IEC 62271-1:2017	NOTE	Harmonized as EN 62271-1:2017 (not modified).
IEC 62271-100:2008	NOTE	Harmonized as EN 62271-100:2009 (not modified).

Annex ZA
(normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

Publication	Year	Title	EN/HD	Year
IEC 60060-1	2010	High-voltage test techniques -- Part 1: General definitions and test requirements	EN 60060-1	2010
IEC 60071-1	2006	Insulation co-ordination -- Part 1: Definitions, principles and rules	EN 60071-1	2006
+ A1	2010		+ A1	2010
IEC 60505	2011	Evaluation and qualification of electrical insulation systems	EN 60505	2011
IEC/TS 60815-1	-	Selection and dimensioning of high-voltage insulators intended for use in polluted conditions - Part 1: Definitions, information and general principles	-	-
ISO 2533	1975	Standard Atmosphere	-	-

CONTENTS

FOREWORD 8
1 Scope 10
2 Normative references 10
3 Terms, definitions, abbreviated terms and symbols 11
3.1 Terms and definitions 11
3.2 Abbreviated terms 11
3.3 Symbols 11
4 Representative voltage stresses in service 16
4.1 Origin and classification of voltage stresses 16
4.2 Characteristics of overvoltage protection devices 17
4.2.1 General remarks 17
4.2.2 Metal-oxide surge arresters without gaps (MOSA) 17
4.2.3 Line surge arresters (LSA) for overhead transmission and distribution lines 19
4.3 Representative voltages and overvoltages 19
4.3.1 Continuous (power-frequency) voltage 19
4.3.2 Temporary overvoltages 20
4.3.3 Slow-front overvoltages 23
4.3.4 Fast-front overvoltages 29
4.3.5 Very-fast-front overvoltages [13] 33
5 Co-ordination withstand voltage 34
5.1 Insulation strength characteristics 34
5.1.1 General 34
5.1.2 Influence of polarity and overvoltage shapes 35
5.1.3 Phase-to-phase and longitudinal insulation 36
5.1.4 Influence of weather conditions on external insulation 36
5.1.5 Probability of disruptive discharge of insulation 37
5.2 Performance criterion 38
5.3 Insulation co-ordination procedures 39
5.3.1 General 39
5.3.2 Insulation co-ordination procedures for continuous (power-frequency) voltage and temporary overvoltage 40
5.3.3 Insulation co-ordination procedures for slow-front overvoltages 40
5.3.4 Insulation co-ordination procedures for fast-front overvoltages 45
6 Required withstand voltage 46
6.1 General remarks 46
6.2 Atmospheric correction 46
6.2.1 General remarks 46
6.2.2 Altitude correction 46
6.3 Safety factors 48
6.3.1 General 48
6.3.2 Ageing 48
6.3.3 Production and assembly dispersion 48
6.3.4 Inaccuracy of the withstand voltage 48
6.3.5 Recommended safety factors (K_S) 49
7 Standard withstand voltage and testing procedures 49

7.1 General remarks 49
7.1.1 Overview 49
7.1.2 Standard switching impulse withstand voltage 49
7.1.3 Standard lightning impulse withstand voltage 50
7.2 Test conversion factors 50
7.2.1 Range I 50
7.2.2 Range II 51
7.3 Determination of insulation withstand by type tests 51
7.3.1 Test procedure dependency upon insulation type 51
7.3.2 Non-self-restoring insulation 52
7.3.3 Self-restoring insulation 52
7.3.4 Mixed insulation 52
7.3.5 Limitations of the test procedures 53
7.3.6 Selection of the type test procedures 54
7.3.7 Selection of the type test voltages 54
8 Special considerations for overhead lines 55
8.1 General remarks 55
8.2 Insulation co-ordination for operating voltages and temporary overvoltages 55
8.3 Insulation co-ordination for slow-front overvoltages 55
8.3.1 General 55
8.3.2 Earth-fault overvoltages 56
8.3.3 Energization and re-energization overvoltages 56
8.4 Insulation co-ordination for lightning overvoltages 56
8.4.1 General 56
8.4.2 Distribution lines 56
8.4.3 Transmission lines 57
9 Special considerations for substations 57
9.1 General remarks 57
9.1.1 Overview 57
9.1.2 Operating voltage 57
9.1.3 Temporary overvoltage 57
9.1.4 Slow-front overvoltages 58
9.1.5 Fast-front overvoltages 58
9.2 Insulation co-ordination for overvoltages 58
9.2.1 Substations in distribution systems with U_m up to 36 kV in range I 58
9.2.2 Substations in transmission systems with U_m between 52,5 kV and 245 kV in range I 59
9.2.3 Substations in transmission systems in range II 60
Annex A (informative) Determination of temporary overvoltages due to earth faults 61
Annex B (informative) Weibull probability distributions 65
B.1 General remarks 65
B.2 Disruptive discharge probability of external insulation 66
B.3 Cumulative frequency distribution of overvoltages 68
Annex C (informative) Determination of the representative slow-front overvoltage due to line energization and re-energization 71
C.1 General remarks 71
C.2 Probability distribution of the representative amplitude of the prospective overvoltage phase-to-earth 71

C.3 Probability distribution of the representative amplitude of the prospective overvoltage phase-to-phase 71
C.4 Insulation characteristic 73
C.5 Numerical example 75
Annex D (informative) Transferred overvoltages in transformers 81
D.1 General remarks 81
D.2 Transferred temporary overvoltages 82
D.3 Capacitively transferred surges 82
D.4 Inductively transferred surges 84
Annex E (informative) Lightning overvoltages 88
E.1 General remarks 88
E.2 Determination of the limit distance (X_p) 88
E.2.1 Protection with arresters in the substation 88
E.2.2 Self-protection of substation 89
E.3 Estimation of the representative lightning overvoltage amplitude 90
E.3.1 General 90
E.3.2 Shielding penetration 90
E.3.3 Back flashovers 91
E.4 Simplified method 93
E.5 Assumed maximum value of the representative lightning overvoltage 95
Annex F (informative) Calculation of air gap breakdown strength from experimental data 96
F.1 General 96
F.2 Insulation response to power-frequency voltages 96
F.3 Insulation response to slow-front overvoltages 97
F.4 Insulation response to fast-front overvoltages 98
Annex G (informative) Examples of insulation co-ordination procedure 102
G.1 Overview 102
G.2 Numerical example for a system in range I (with nominal voltage of 230 kV) 102
G.2.1 General 102
G.2.2 Part 1: no special operating conditions 103
G.2.3 Part 2: influence of capacitor switching at station 2 110
G.2.4 Part 3: flow charts related to the example of Clause G.2 112
G.3 Numerical example for a system in range II (with nominal voltage of 735 kV) 117
G.3.1 General 117
G.3.2 Step 1: determination of the representative overvoltages – values of U_{rp} 117
G.3.3 Step 2: determination of the co-ordination withstand voltages – values of U_{cw} 118
G.3.4 Step 3: determination of the required withstand voltages – values of U_{rw} 119
G.3.5 Step 4: conversion to switching impulse withstand voltages (SIWV) 120
G.3.6 Step 5: selection of standard insulation levels 120
G.3.7 Considerations relative to phase-to-phase insulation co-ordination 121
G.3.8 Phase-to-earth clearances 122
G.3.9 Phase-to-phase clearances 122
G.4 Numerical example for substations in distribution systems with U_m up to 36 kV in range I 123
G.4.1 General 123

G.4.2 Step 1: determination of the representative overvoltages – values of U_{rp} 123
G.4.3 Step 2: determination of the co-ordination withstand voltages – values of U_{cw} 124
G.4.4 Step 3: determination of required withstand voltages – values of U_{rw} 125
G.4.5 Step 4: conversion to standard short-duration power-frequency and lightning impulse withstand voltages 126
G.4.6 Step 5: selection of standard withstand voltages 126
G.4.7 Summary of insulation co-ordination procedure for the example of Clause G.4 127
Annex H (informative) Atmospheric correction – Altitude correction 129
H.1 General principles 129
H.1.1 Atmospheric correction in standard tests 129
H.1.2 Task of atmospheric correction in insulation co-ordination 130
H.2 Atmospheric correction in insulation co-ordination 132
H.2.1 Factors for atmospheric correction 132
H.2.2 General characteristics for moderate climates 132
H.2.3 Special atmospheric conditions 133
H.2.4 Altitude dependency of air pressure 134
H.3 Altitude correction 135
H.3.1 Definition of the altitude correction factor 135
H.3.2 Principle of altitude correction 136
H.3.3 Standard equipment operating at altitudes up to 1 000 m 137
H.3.4 Equipment operating at altitudes above 1 000 m 137
H.4 Selection of the exponent *m* 138
H.4.1 General 138
H.4.2 Derivation of exponent m for switching impulse voltage 138
H.4.3 Derivation of exponent *m* for critical switching impulse voltage 141
Annex I (informative) Evaluation method of non-standard lightning overvoltage shape for representative voltages and overvoltages 144
I.1 General remarks 144
I.2 Lightning overvoltage shape 144
I.3 Evaluation method for GIS 144
I.3.1 Experiments 144
I.3.2 Evaluation of overvoltage shape 145
I.4 Evaluation method for transformer 145
I.4.1 Experiments 145
I.4.2 Evaluation of overvoltage shape 145
Annex J (informative) Insulation co-ordination for very-fast-front overvoltages in UHV substations 152
J.1 General 152
J.2 Influence of disconnector design 152
J.3 Insulation co-ordination for VFFO 153
Bibliography 155

Figure 1 – Range of 2 % slow-front overvoltages at the receiving end due to line energization and re-energization 25
Figure 2 – Ratio between the 2 % values of slow-front overvoltages phase-to-phase and phase-to-earth 26
Figure 3 – Diagram for surge arrester connection to the protected object 33

Figure 4 – Distributive discharge probability of self-restoring insulation described on a linear scale 41

Figure 5 – Disruptive discharge probability of self-restoring insulation described on a Gaussian scale 41

Figure 6 – Evaluation of deterministic co-ordination factor K_{cd} 42

Figure 7 – Evaluation of the risk of failure 43

Figure 8 – Risk of failure of external insulation for slow-front overvoltages as a function of the statistical co-ordination factor K_{cs} 45

Figure 9 – Dependence of exponent m on the co-ordination switching impulse withstand voltage 47

Figure 10 – Probability P of an equipment to pass the test dependent on the difference K between the actual and the rated impulse withstand voltage 53

Figure 11 – Example of a schematic substation layout used for the overvoltage stress location 57

Figure A.1 – Earth fault factor k on a base of X_0/X_1 for $R_1/X_1 = R = 0$ 62

Figure A.2 – Relationship between R_0/X_1 and X_0/X_1 for constant values of earth fault factor k where $R_1 = 0$ 62

Figure A.3 – Relationship between R_0/X_1 and X_0/X_1 for constant values of earth fault factor k where $R_1 = 0{,}5\ X_1$ 63

Figure A.4 – Relationship between R_0/X_1 and X_0/X_1 for constant values of earth fault factor k where $R_1 = X_1$ 63

Figure A.5 – Relationship between R_0/X_1 and X_0/X_1 for constant values of earth fault factor k where $R_1 = 2X_1$ 64

Figure B.1 – Conversion chart for the reduction of the withstand voltage due to placing insulation configurations in parallel 70

Figure C.1 – Example for bivariate phase-to-phase overvoltage curves with constant probability density and tangents giving the relevant 2 % values 77

Figure C.2 – Principle of the determination of the representative phase-to-phase overvoltage U_{pre} 78

Figure C.3 – Schematic phase-phase-earth insulation configuration 79

Figure C.4 – Description of the 50 % switching impulse flashover voltage of a phase-phase-earth insulation 79

Figure C.5 – Inclination angle of the phase-to-phase insulation characteristic in range "b" dependent on the ratio of the phase-phase clearance D to the height H_t above earth 80

Figure D.1 – Distributed capacitances of the windings of a transformer and the equivalent circuit describing the windings 86

Figure D.2 – Values of factor J describing the effect of the winding connections on the inductive surge transference 87

Figure H.1 – Principle of the atmospheric correction during test of a specified insulation level according to the procedure of IEC 60060-1 130

Figure H.2 – Principal task of the atmospheric correction in insulation co-ordination according to IEC 60071-1 131

Figure H.3 – Comparison of atmospheric correction $\delta \times k_h$ with relative air pressure p/p_0 for various weather stations around the world 133

Figure H.4 – Deviation of simplified pressure calculation by exponential function in this document from the temperature dependent pressure calculation of ISO 2533 135

Figure H.5 – Principle of altitude correction: decreasing withstand voltage U_{10} of equipment with increasing altitude 136

Figure H.6 – Sets of *m*-curves for standard switching impulse voltage including the variations in altitude for each gap factor 140

Figure H.7 – Exponent *m* for standard switching impulse voltage for selected gap factors covering altitudes up to 4 000 m 141

Figure H.8 – Sets of *m*-curves for critical switching impulse voltage including the variations in altitude for each gap factor 142

Figure H.9 – Exponent *m* for critical switching impulse voltage for selected gap factors covering altitudes up to 4 000 m 142

Figure H.10 – Accordance of *m*-curves from Figure 9 with determination of exponent *m* by means of critical switching impulse voltage for selected gap factors and altitudes 143

Figure I.1 – Examples of lightning overvoltage shapes 147

Figure I.2 – Example of insulation characteristics with respect to lightning overvoltages of the SF_6 gas gap (Shape E) 148

Figure I.3 – Calculation of duration time T_d 148

Figure I.4 – Shape evaluation flow for GIS and transformer 149

Figure I.5 – Application to GIS lightning overvoltage 150

Figure I.6 – Example of insulation characteristics with respect to lightning overvoltage of the turn-to-turn insulation (Shape C) 150

Figure I.7 – Application to transformer lightning overvoltage 151

Figure J.1 – Insulation co-ordination for very-fast-front overvoltages 154

Table 1 – Test conversion factors for range I, to convert required SIWV to SDWV and LIWV 51

Table 2 – Test conversion factors for range II to convert required SDWV to SIWV 51

Table 3 – Selectivity of test procedures B and C of IEC 60060-1 53

Table B.1 – Breakdown voltage versus cumulative flashover probability – Single insulation and 100 parallel insulations 67

Table E.1 – Corona damping constant K_{co} 89

Table E.2 – Factor *A* for various overhead lines 94

Table F.1 – Typical gap factors *K* for switching impulse breakdown phase-to-earth (according to [1] and [4]) 100

Table F.2 – Gap factors for typical phase-to-phase geometries 101

Table G.1 – Summary of minimum required withstand voltages obtained for the example shown in G.2.2 109

Table G.2 – Summary of required withstand voltages obtained for the example shown in G.2.3 111

Table G.3 – Values related to the insulation co-ordination procedure for the example in G.4 128

Table H.1 – Comparison of functional expressions of Figure 9 with the selected parameters from the derivation of *m*-curves with critical switching impulse 143

Table I.1 – Evaluation of the lightning overvoltage in the GIS of UHV system 148

Table I.2 – Evaluation of lightning overvoltage in the transformer of 500 kV system 151

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

INSULATION CO-ORDINATION –

Part 2: Application guidelines

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60071-2 has been prepared by IEC technical committee 28: Insulation co-ordination.

This fourth edition cancels and replaces the third edition published in 1996. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

a) the annex on clearance in air to assure a specified impulse withstand voltage installation is deleted because the annex in IEC 60071-1 is overlapped;
b) 4.2 and 4.3 on surge arresters are updated;
c) 4.3.5 on very-fast-front overvoltages is revised. Annex J on insulation co-ordination for very-fast-front overvoltages in UHV substations is added;
d) Annex H on atmospheric correction – altitude correction is added.

e) Annex I on evaluation method of non-standard lightning overvoltage shape is added.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
28/255/FDIS	28/256/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

It has the status of a horizontal standard in accordance with IEC Guide 108.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INSULATION CO-ORDINATION –

Part 2: Application guidelines

1 Scope

This part of IEC 60071 constitutes application guidelines and deals with the selection of insulation levels of equipment or installations for three-phase electrical systems. Its aim is to give guidance for the determination of the rated withstand voltages for ranges I and II of IEC 60071-1 and to justify the association of these rated values with the standardized highest voltages for equipment.

This association is for insulation co-ordination purposes only. The requirements for human safety are not covered by this document.

This document covers three-phase systems with nominal voltages above 1 kV. The values derived or proposed herein are generally applicable only to such systems. However, the concepts presented are also valid for two-phase or single-phase systems.

This document covers phase-to-earth, phase-to-phase and longitudinal insulation.

This document is not intended to deal with routine tests. These are to be specified by the relevant product committees.

The content of this document strictly follows the flow chart of the insulation co-ordination process presented in Figure 1 of IEC 60071-1:2006. Clauses 4 to 7 correspond to the squares in this flow chart and give detailed information on the concepts governing the insulation co-ordination process which leads to the establishment of the required withstand levels.

This document emphasizes the necessity of considering, at the very beginning, all origins, all classes and all types of voltage stresses in service irrespective of the range of highest voltage for equipment. Only at the end of the process, when the selection of the standard withstand voltages takes place, does the principle of covering a particular service voltage stress by a standard withstand voltage apply. Also, at this final step, this document refers to the correlation made in IEC 60071-1 between the standard insulation levels and the highest voltage for equipment.

The annexes contain examples and detailed information which explain or support the concepts described in the main text, and the basic analytical techniques used.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60060-1:2010, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60071-1:2006, *Insulation co-ordination – Part 1: Definitions, principles and rules*
IEC 60071-1:2006/AMD1:2010