

ANSI/AMCA Standard 205-19

Energy Efficiency Classification for Fans

An American National Standard
Approved by ANSI on May 3, 2019



Air Movement and Control Association International

AMCA Corporate Headquarters

30 W. University Drive, Arlington Heights, IL 60004-1893, USA
communications@amca.org ■ Ph: +1-847-394-0150 ■ www.amca.org

ANSI/AMCA Standard 205-19

Energy Efficiency Classifications for Fans



Air Movement and Control Association International
30 West University Drive
Arlington Heights, Illinois
60004

AMCA Standard

Authority AMCA Standard 205-19 was adopted by the membership of the Air Movement and Control Association International Inc. on April 24, 2019. It was approved as an American National Standard on May 3, 2019.

Copyright © 2012 by the Air Movement and Control Association International Inc.

All rights reserved. Reproduction or translation of any part of this work beyond that permitted by Sections 107 and 108 of the United States Copyright Act without the permission of the copyright owner is unlawful. Requests for permission or further information should be addressed to the executive director, Air Movement and Control Association International Inc. at 30 West University Drive, Arlington Heights, IL 60004-1893, U.S.A.

Objections The Air Movement and Control Association (AMCA) International Inc. will consider and take action upon all written complaints regarding its standards, certification programs or interpretations thereof. For information on procedures for submitting and handling complaints, write to:

AMCA International
30 West University Drive
Arlington Heights, IL 60004-1893
U.S.A.

European AMCA
Avenue des Arts, numéro 46
à Bruxelles (1000 Bruxelles)

Asia AMCA Sdn Bhd
No. 7, Jalan SiLC 1/6,
Kawasan Perindustrian SiLC Nusajaya,
Mukim Jelutong, 79200 Nusajaya, Johor
Malaysia

Disclaimer AMCA uses its best efforts to produce publications for the benefit of the industry and the public in light of available information and accepted industry practices. However, AMCA does not guarantee, certify or assure the safety or performance of any products, components or systems tested, designed, installed or operated in accordance with AMCA publications or that any tests conducted under its publications will be non-hazardous or free from risk.

Review Committee

Armin Hauer (Chair)	ebm-papst Inc.
Lee Buddrus	Acme Engineering & Manufacturing Corporation
Sushil Choudhury	Blowtech Air Devices Pvt. Ltd.
Tanmoy Kumar Choudhury	Maico Gulf LLC
Franco Cincotti	Comefri USA
Francois Desautels	Topcool
Sameh Ezzat	Hammam Industries & Co.
Sham Morten Gabr	Multi-Wing
Peter Holt	Novenco Building & Industry
Kim G. Osborn	Nortek Air Solutions
Brandon Parker	Ketchum and Walton
Murat Pilge	CVS Havalandirma A. S.
James McNeill Shaw	Howden North America
Vikas Shevale	Vibrosolve India Private Limited
Ola Wettergren	Systemair
Michael Wolf	Greenheck Fan Corporation

Contents

Contents	4
Energy Efficiency Classification for Fans	5
1. Purpose.....	5
2. Scope.....	5
3. Normative References	5
4. Definitions/Symbols.....	5
4.1 Definitions	5
4.1.1 Fan	5
4.1.2 Impeller diameter	5
4.1.3 Fan drives (transmission, motor/control system).....	6
4.1.4 Fan without a drive.....	6
4.1.5 Fan with a drive.....	6
4.1.6 Air.....	6
4.1.7 Fan pressures	8
4.1.7.1 Fan total pressure (P_t)	8
4.1.7.2 Fan velocity pressure (P_v).....	8
4.1.8 Fan air power (H_o).....	8
4.1.9 Fan shaft power (H_{sh}).....	8
4.1.10 Fan impeller power (H_i).....	9
4.1.11 Fan peak efficiency (η_{pk}).....	9
4.1.12 Fan efficiency grade (FEG).....	9
4.2 Symbols	9
5. General	10
5.1 Use of test installation categories.....	10
5.2 Fan energy efficiency calculations	10
5.2.1 Efficiency of a fan without drives	10
5.2.2 Efficiency of a direct driven fan without consideration of the drives	10
6. Efficiency Classifications for Fans	10
6.1 General.....	10
6.2 FEG classification of fan efficiency.....	10
7.(Informative) Use of FEG in Codes and Specifications.....	14
Annex A Energy Efficiency Grades for a Fan Without a Drive (Normative).....	13
Annex B Fan Efficiency Range for System Fan Selection (Informative).....	16

Energy Efficiency Classification for Fans

1. Purpose

This standard defines the energy efficiency classification for fans.

2. Scope

The scope includes fans having an impeller diameter of 125 mm (5 in.) or greater, operating with an impeller shaft power of 750 W (1 hp) and above and having a fan total efficiency calculated according to one of the following fan test standards: ANSI/AMCA Standard 210, AMCA Standard 260 or ISO 5801. All other fans are excluded. This standard only applies to the fan, not the fan drive or the fan system.

3. Normative References

The following referenced documents shall be utilized for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document, including any amendments, applies.

ANSI/AMCA Standard 99, Standards Handbook

ANSI/AMCA Standard 210, Laboratory Methods of Testing Fans for Certified Aerodynamic Performance Rating

AMCA Standard 260, Laboratory Methods of Testing Induced Flow Fans for Rating

IEEE 112-2004, Standard Test Procedure for Polyphase Induction Motors and Generators

IEEE 114-2001, Standard Test Procedure for Single-Phase Induction Motors

ISO 5801, Industrial Fans - Performance Testing Using Standardized Airways

ISO 12759:2010, Fans - Efficiency Classification for Fans

ISO 13348:2007, Industrial Fans - Tolerances, Methods of Conversion and Technical Data Presentation

ISO 13349:2008, Industrial Fans - Vocabulary and Definitions of Categories

4. Definitions/Symbols

For the purpose of this standard, the definitions, units of measure and symbols in this section apply.

Definitions for fan pressures and efficiencies are found in the standards referenced in Section 3.

4.1 Definitions

4.1.1 Fan

A rotary machine that imparts energy to an air stream and by means of one or more impellers fitted with blades to maintain quasi continuous flow with a fan pressure rise that does not normally exceed 30 kPa (120 in. wg).

Note: The pressure limit corresponds approximately to a fan specific work of 25 kJ/kg.

4.1.2 Impeller diameter

For the purpose of fan efficiency grade (FEG) classification, impeller diameter is the largest diameter of the circle inscribed by the rotating impeller blade tips.