BS EN IEC 60664-1:2020



BSI Standards Publication

Insulation coordination for equipment within low-voltage supply systems

Part 1: Principles, requirements and tests

bsi.

National foreword

This British Standard is the UK implementation of EN IEC 60664-1:2020. It is identical to IEC 60664-1:2020. It supersedes BS EN 60664-1:2007, which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee GEL/109, Insulation co-ordination for low voltage equipment.

A list of organizations represented on this committee can be obtained on request to its committee manager.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2020
Published by BSI Standards Limited 2020

ISBN 978 0 580 97044 3

ICS 29.080.30

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 July 2020.

Amendments/corrigenda issued since publication

Date	Text affected

EUROPEAN STANDARD

NORME EUROPÉENNE

EUROPÄISCHE NORM

EN IEC 60664-1

July 2020

ICS 29.080.30

Supersedes EN 60664-1:2007 and all of its amendments and corrigenda (if any)

English Version

Insulation coordination for equipment within low-voltage supply systems - Part 1: Principles, requirements and tests (IEC 60664-1:2020)

Coordination de l'isolement des matériels dans les réseaux d'énergie électrique à basse tension - Partie 1: Principes, exigences et essais (IEC 60664-1:2020)

Isolationskoordination für elektrische Betriebsmittel in Niederspannungsanlagen - Teil 1: Grundsätze, Anforderungen und Prüfungen (IEC 60664-1:2020)

This European Standard was approved by CENELEC on 2020-06-30. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

© 2020 CENELEC All rights of exploitation in any form and by any means reserved worldwide for CENELEC Members.

European foreword

The text of document 109/183/FDIS, future edition 3 of IEC 60664-1, prepared by IEC/TC 109 "Insulation co-ordination for low-voltage equipment" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN IEC 60664-1:2020.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2021-03-30
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2023-06-30

This document supersedes EN 60664-1:2007 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 60664-1:2020 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60038:2009	NOTE	Harmonized as EN 60038:2011 (modified)
IEC 60216 (series)	NOTE	Harmonized as EN 60216 (series)
IEC 60068 (series)	NOTE	Harmonized as EN 60068 (series)
IEC 60068-1:2013	NOTE	Harmonized as EN 60068-1:2014 (not modified)
IEC 60085:2007	NOTE	Harmonized as EN 60085:2008 (not modified)
IEC 60112:2003	NOTE	Harmonized as EN 60112:2003 (not modified)
IEC 60364-4-44:2007	NOTE	Harmonized as HD 60364-4-442:2012 (modified)
IEC 60529	NOTE	Harmonized as EN 60529
IEC 60664-3:2016	NOTE	Harmonized as EN 60664-3:2017 (not modified)
IEC 60664-4:2005	NOTE	Harmonized as EN 60664-4:2006 (not modified)
IEC 61000-4-5:2014	NOTE	Harmonized as EN 61000-4-5:2014 (not modified)

IEC 60664-1

Edition 3.0 2020-05

INTERNATIONAL STANDARD

NORME INTERNATIONALE

colour inside

BASIC SAFETY PUBLICATION
PUBLICATION FONDAMENTALE DE SÉCURITÉ

Insulation coordination for equipment within low-voltage supply systems – Part 1: Principles, requirements and tests

Coordination de l'isolement des matériels dans les réseaux d'énergie électrique à basse tension – Partie 1: Principes, exigences et essais

INTERNATIONAL ELECTROTECHNICAL COMMISSION

COMMISSION ELECTROTECHNIQUE INTERNATIONALE

ICS 29.080.30

ISBN 978-2-8322-8287-8

Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.

® Registered trademark of the International Electrotechnical Commission
Marque déposée de la Commission Electrotechnique Internationale

CONTENTS

FOREWORD 6
1 Scope 8
2 Normative references 8
3 Terms, definitions and abbreviated terms 9
3.1 Terms and definitions 9
3.2 Abbreviated terms 15
4 Basic technical characteristics for insulation coordination 15
4.1 General 15
4.2 Voltages 16
4.2.1 General aspects 16
4.2.2 Transient overvoltages 17
4.2.3 Temporary overvoltages 18
4.2.4 Recurring peak voltage 18
4.2.5 Steady-state working voltage 19
4.2.6 Steady-state peak voltage 19
4.3 Overvoltage categories 19
4.3.1 General 19
4.3.2 Equipment energized directly from the mains supply 19
4.3.3 Systems and equipment not energized directly from the mains supply 20
4.4 Frequency 20
4.4.1 General 20
4.4.2 Solid insulation 20
4.5 Pollution 20
4.5.1 General 20
4.5.2 Degrees of pollution in the micro-environment 21
4.5.3 Conditions of conductive pollution 21
4.6 Insulating material 21
4.6.1 Solid insulation 21
4.6.2 Stresses 22
4.6.3 Comparative tracking index (CTI) 23
4.7 Environmental aspects 24
4.7.1 General 24
4.7.2 Altitude 24
4.7.3 Temperature 24
4.7.4 Vibrations 24
4.7.5 Humidity 24
4.8 Duration of voltage stress 24
4.9 Electrical field distribution 25
5 Design for insulation coordination 25
5.1 General 25
5.1.1 Means of insulation coordination 25
5.1.2 Frequency above 30 kHz 25
5.1.3 Reduced distances due to coating or potting 25
5.1.4 Equipment which are not connected to public low-voltage systems. 25
5.2 Dimensioning of clearances 25
5.2.1 General 25

5.2.2 Dimensioning criteria for clearances 26
5.2.3 Other factors involving clearances 26
5.2.4 Dimensioning of clearances of functional insulation 27
5.2.5 Dimensioning of clearances of basic insulation, supplementary insulation and reinforced insulation 27
5.3 Dimensioning of creepage distances 28
5.3.1 General 28
5.3.2 Dimensioning criteria of creepage distances 29
5.3.3 Other factors involving creepage distances 30
5.3.4 Dimensioning of creepage distances of functional insulation 31
5.3.5 Dimensioning of creepage distances of basic insulation, supplementary insulation and reinforced insulation 31
5.4 Requirements for design of solid insulation 32
5.4.1 General 32
5.4.2 Voltage stress 32
5.4.3 Withstand of voltage stresses 32
5.4.4 Withstand on environmental stresses 34
6 Tests and measurements 34
6.1 General 34
6.2 Verification of clearances 35
6.2.1 General 35
6.2.2 Test voltages 35
6.3 Verification of creepage distances 37
6.4 Verification of solid insulation 37
6.4.1 General 37
6.4.2 Selection of tests 38
6.4.3 Conditioning 39
6.4.4 Impulse voltage test 39
6.4.5 AC power frequency voltage test 40
6.4.6 Partial discharge test 40
6.4.7 DC voltage test 42
6.4.8 High-frequency voltage test 43
6.5 Performing dielectric tests on complete equipment 43
6.5.1 General 43
6.5.2 Parts to be tested 43
6.5.3 Preparation of equipment circuits 44
6.5.4 Test voltage values 44
6.5.5 Test criteria 44
6.6 Other tests 44
6.6.1 Test for purposes other than insulation coordination 44
6.6.2 Sampling and routine tests 44
6.6.3 Measurement accuracy of test parameters 44
6.7 Measurement of the attenuation of the transient overvoltages 45
6.8 Measurement of clearances and creepage distances 45
Annex A (informative) Basic data on withstand characteristics of clearances 51
Annex B (informative) Nominal voltages of mains supply for different modes of overvoltage control 56
Annex C (normative) Partial discharge test methods 58
C.1 Test circuits 58

C.1.1 General 58
C.1.2 Test circuit for earthed test specimen (Figure C.1) 58
C.1.3 Test circuit for unearthed test specimen (Figure C.2) 59
C.1.4 Selection criteria 59
C.1.5 Measuring impedance 59
C.1.6 Coupling capacitor C_k 59
C.1.7 Filter 59
C.2 Test parameters 59
C.2.1 General 59
C.2.2 Requirements for the test voltage 60
C.2.3 Climatic conditions 60
C.3 Requirements for measuring instruments 60
C.3.1 General 60
C.3.2 Classification of PD meters 60
C.3.3 Bandwidth of the test circuit 61
C.4 Calibration 61
C.4.1 Calibration of discharge magnitude before the noise level measurement 61
C.4.2 Verification of the noise level 62
C.4.3 Calibration for the PD test 63
C.4.4 Calibration pulse generator 63
Annex D (informative) Additional information on partial discharge test methods 64
D.1 Measurement of partial discharge (PD), PD inception and extinction voltage 64
D.2 Description of PD test circuits (Figure D.1) 64
D.3 Precautions for reduction of noise 65
D.3.1 General 65
D.3.2 Sources in the non-energized test circuit 65
D.3.3 Sources in the energized test circuit 65
D.3.4 Measures for reduction of noise 65
D.4 Application of multiplying factors for test voltages 65
D.4.1 General 65
D.4.2 Example 1 (circuit connected to mains supply) 66
D.4.3 Example 2 (internal circuit with maximum recurring peak voltage U_{rp}) 66
Annex E (informative) Comparison of creepage distances specified in Table F.5 and clearances in Table A.1 67
Annex F (normative) Tables 68
Annex G (informative) Determination of clearance distances according to 5.2 77
Annex H (informative) Determination of creepage distances according to 5.3 79
Bibliography 81

Figure 1 – Recurring peak voltage 19
Figure 2 – Determination of the width (W) and height (H) of a rib 31
Figure 3 – Test voltages 42
Figure 4 – Across the groove 46
Figure 5 – Contour of the groove 47
Figure 6 – Contour of the groove with angle 47
Figure 7 – Contour of rib 47
Figure 8 – Uncemented joint with grooves less than X 48

Figure 9 – Uncemented joint with grooves equal to or more than X 48
Figure 10 – Uncemented joint with a groove on one side less than X 49
Figure 11 – Creepage distance and clearance through an uncemented joint 49
Figure 12 – Creepage distance and clearance to a head of screw more than X 49
Figure 13 – Creepage distance and clearance to a head of screw less than X 50
Figure 14 – Creepage distance and clearance with conductive floating part 50
Figure A.1 – Withstand voltage at 2 000 m above sea level 53
Figure A.2 – Experimental data measured at approximately sea level and their low limits for inhomogeneous field 54
Figure A.3 – Experimental data measured at approximately sea level and their low limits for homogeneous field 55
Figure C.1 – Earthed test specimen 58
Figure C.2 – Unearthed test specimen 59
Figure C.3 – Calibration for earthed test specimen 62
Figure C.4 – Calibration for unearthed test specimen 62
Figure D.1 – Partial discharge test circuits 64
Figure E.1 – Comparison between creepage distances specified in Table F.5 and clearances in Table A.1 67
Figure G.1 – Determination of clearance distances according to 5.2 *(1 of 2)* 77
Figure H.1 – Determination of creepage distances according to 5.3 *(1 of 2)* 79

Table 1 – Dimensioning of grooves 46
Table A.1 – Withstand voltages for an altitude of 2 000 m above sea level *(1 of 2)* 51
Table A.2 – Altitude correction factors for clearance correction 52
Table B.1 – Inherent control or equivalent protective control 56
Table B.2 – Cases where protective control is necessary and control is provided by surge protective device having a ratio of voltage protection level to rated voltage not smaller than that specified in IEC 61643 (all parts) 57
Table F.1 – Rated impulse withstand voltage for equipment energized directly from the mains supply 68
Table F.2 – Clearances to withstand transient overvoltages 69
Table F.3 – Single-phase three-wire or two-wire AC or DC systems 70
Table F.4 – Three-phase four-wire or three-wire AC systems 71
Table F.5 – Creepage distances to avoid failure due to tracking *(1 of 2)* 72
Table F.6 – Test voltages for verifying clearances only at different altitudes 74
Table F.7 – Severities for conditioning of solid insulation 74
Table F.8 – Dimensioning of clearances to withstand steady-state peak voltages, temporary overvoltages or recurring peak voltages [b] 75
Table F.9 – Additional information concerning the dimensioning of clearances to avoid partial discharge 75
Table F.10 – Altitude correction factors for clearance correction 76

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

INSULATION COORDINATION FOR EQUIPMENT WITHIN LOW-VOLTAGE SUPPLY SYSTEMS –

Part 1: Principles, requirements and tests

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60664-1 has been prepared by IEC technical committee 109: Insulation co-ordination for low-voltage equipment.

This third edition cancels and replaces the second edition published in 2007. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

a) update of the Scope, Clauses 2 and 3,
b) new structure for Clauses 4 and 5,
c) addition of 1 500 V DC into tables in Annex B and F,
d) update of distances altitude correction in a new Table F.10,
e) addition of Annex G with a flowchart for clearances,

f) addition of Annex H with a flowchart for creepage distances.

It has the status of a basic safety publication in accordance with IEC Guide 104.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
109/183/FDIS	109/186/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60664 series, published under the general title *Insulation coordination for equipment within low-voltage supply systems*, can be found on the IEC website.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

In this document, the following print type is used:

– **Terms defined in Clause 3: in bold type**.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INSULATION COORDINATION FOR EQUIPMENT WITHIN LOW-VOLTAGE SUPPLY SYSTEMS –

Part 1: Principles, requirements and tests

1 Scope

This part of IEC 60664 deals with **insulation coordination** for equipment having a **rated voltage** up to AC 1 000 V or DC 1 500 V connected to **low-voltage supply systems**.

This document applies to frequencies up to 30 kHz.

NOTE 1 Requirements for **insulation coordination** for equipment within **low-voltage supply systems** with rated frequencies above 30 kHz are given in IEC 60664-4.

NOTE 2 Higher voltages can exist in internal circuits of the equipment.

It applies to equipment for use up to 2 000 m above sea level and provides guidance for use at higher altitudes (See 5.2.3.4).

It provides requirements for technical committees to determine **clearances**, **creepage distances** and criteria for **solid insulation**. It includes methods of electrical testing with respect to **insulation coordination**.

The minimum **clearances** specified in this document do not apply where ionized gases are present. Special requirements for such situations can be specified at the discretion of the relevant technical committee.

This document does not deal with distances:

– through liquid insulation;

– through gases other than air;

– through compressed air.

This basic safety publication focusing on safety essential requirements is primarily intended for use by technical committees in the preparation of standards in accordance with the principles laid down in IEC Guide 104 and ISO/IEC Guide 51.

One of the responsibilities of a technical committee is, wherever applicable, to make use of basic safety publications in the preparation of its publications.

However, in case of missing specified values for **clearances**, **creepage distances** and requirements for **solid insulation** in the relevant product standards, or even missing standards, this document applies.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-2-2, *Environmental testing – Part 2-2: Tests – Tests B: Dry heat*