



Member of the FM Global Group

Examination Standard for Centrifugal Fire Pumps (Horizontal, End Suction Type)

Class Number 1319

December 2020

Foreword

This standard is intended to verify that the products and services described will meet stated conditions of performance, safety and quality useful to the ends of property conservation. The purpose of this standards is to present the criteria for examination of various types of products and services.

Examination in accordance with this standard shall demonstrate compliance and verify that quality control in manufacturing shall ensure a consistent and reliable product.

Table of Contents

1. INTRODUCTION	1
1.1 Purpose	1
1.2 Scope	1
1.3 Basis for Requirements	1
1.4 Basis for Certification	2
1.5 Basis for Continued Certification	2
1.6 Effective Date	2
1.7 System of Units	2
1.8 Normative References	2
1.9 Terms and Definitions	3
2. GENERAL INFORMATION	6
2.1 Product Information	6
2.2 Application Requirements	6
2.3 Requirements for Samples for Examination	6
3. GENERAL REQUIREMENTS	2
3.1 Review of Documentation	2
3.2 Physical or Structural Features	2
3.2.1 Pump.....	2
3.2.2 Pump Casing.....	2
3.2.3 Water Passages.....	2
3.2.4 Impeller.....	2
3.2.5 Shaft.....	2
3.2.6 Shaft Seals.....	3
3.2.7 Bearings.....	5
3.2.8 Coupling.....	6
3.2.9 Circulation Relief Valve.....	6
3.2.10 Electric Motor.....	6
3.2.11 Miscellaneous Components.....	6
3.3 Pump Package	7
3.4 Materials	7
3.5 Markings	7
3.6 Manufacturer’s Installation and Operation Instructions	8
3.7 Calibration	8
3.8 Tolerances	8
4. PERFORMANCE REQUIREMENTS	9
4.1 Design and Calculation Review	9
4.2 Performance	9
4.3 Suction Lift	9
4.4 Flange and Gasket Tightness	10
4.5 Hydrostatic Strength	10
4.6 One Hour Test (Mechanical Seal Pumps Only)	10
4.7 Test Procedure	11
4.8 Additional Tests	11
5. OPERATIONS REQUIREMENTS	12
5.1 Demonstrated Quality Control Program	12
5.2 Surveillance Audit	12
5.3 Manufacturer’s Responsibilities	13
5.4 Manufacturing and Production Tests	13
APPENDIX A:	1
Appendix A is left intentionally blank.....	1

Appendix B is intentionally blank	1
APPENDIX C: Test Procedures	24
C.1 Capacity Measurements	24
C.2 Head Measurements	26
C.3 Power Measurements	26
C.4 Speed Measurement	27
C.5 Time Measurement	27
APPENDIX D: Fire Pump Unit (Packages)	28
APPENDIX E: Tolerance	29
APPENDIX F: Figures	30
Figure F-1. End Suction Centrifugal Fire Pump, Overhung Impeller, Single Stage.....	30

1. INTRODUCTION

1.1 Purpose

- 1.1.1 This standard states testing and certification requirements for horizontal, end suction type, centrifugal fire pumps that supply water to fire protection systems. These pumps must be available for many years to operate reliably at rated capacities and pressures during emergency fire incidents, despite being idle for extended periods.
- 1.1.2 Testing and certification criteria may include, but are not limited to, performance requirements, marking requirements, examination of manufacturing facility(ies), audit of quality assurance procedures, and a surveillance audit program.

1.2 Scope

- 1.2.1 This standard encompasses the design and performance requirements for horizontal, end suction type, centrifugal fire pumps for use in fire protection systems. Certification is limited to horizontal, end suction type, centrifugal pumps which have a rated pressure of at least 40 psi (275 kPa). In cases where metric sized horizontal, end suction type, centrifugal fire pumps are to be examined for certification, test criteria comparable to the United States equivalent size shall be used. This standard encompasses the requirements for single and multistage end suction fire pumps.
- 1.2.2 Requirements for other types of centrifugal fire pumps are detailed in the following standards:

<i>Class</i>	<i>Centrifugal Fire Pump Type</i>
1310	Multi Stage, Multi Outlet
1311	Split-Case Type, (Axial or Radial)
1312	Vertical Shaft Turbine Type
1370	Vertical Turbine Barrel Type
1371	In-Line Type

- 1.2.3 Requirements for other major components in the pump package are detailed in the following standards:

<i>Class</i>	<i>Equipment</i>
1046	Fire Pump Flowmeter Systems
1321/1323	Controllers for Electric Motor Driven and Diesel Engine Driven Fire Pumps
1333	Diesel Engine Fire Pump Drivers
1336	Fire Pump Couplings and Flexible Connecting Shafts for Fire Protection Service
1359	Trim Water Pressure Relief Valves
2311	Pressure Gauges for Fire Protection Systems

1.3 Basis for Requirements

- 1.3.1 The requirements of this standard are based on experience, research and testing, and/or the standards of other organizations. The advice of manufacturers, users, trade associations, jurisdictions and/or loss control specialists was also considered.
- 1.3.2 The requirements of this standard reflect tests and practices used to examine characteristics of horizontal, end suction type, centrifugal fire pumps for the purpose of obtaining certification. Horizontal, end suction type, centrifugal fire pumps having characteristics not anticipated by this standard may be certified if performance equal, or superior, to that required by this standard is demonstrated.