



*Member of the FM Global Group*

# **Examination Standard for Carbon Dioxide Extinguishing Systems**

**Class Number 5420**

**September 2020**

---

# Foreword

This standard is intended to verify that the products and services described will meet stated conditions of performance, safety and quality useful to the ends of property conservation. The purpose of this standard is to present the criteria for examination of various types of products and services.

Examination in accordance with this standard shall demonstrate compliance and verify that quality control in manufacturing shall ensure a consistent and reliable product.

---

# TABLE OF CONTENTS

<b>1.</b>	<b>INTRODUCTION .....</b>	<b>1</b>
1.1	Purpose.....	1
1.2	Scope.....	1
1.3	Basis for Requirements.....	1
1.4	Basis for Certification .....	2
1.5	Basis for Continued Certification .....	2
1.6	Effective Date.....	2
1.7	System of Units.....	2
1.8	Normative References .....	3
1.9	Definitions.....	3
<b>2.</b>	<b>GENERAL INFORMATION.....</b>	<b>6</b>
2.1	Certification Application Requirements .....	6
2.2	Requirements for Samples for Examination.....	6
<b>3.</b>	<b>GENERAL REQUIREMENTS.....</b>	<b>7</b>
3.1	Review of Documentation.....	7
3.2	Physical or Structural Construction Features .....	7
3.2.1	Operating Range .....	7
3.2.2	Materials .....	7
3.2.3	Control.....	7
3.2.4	Strength.....	8
3.2.5	Pressure Vessels .....	8
3.2.6	Discharge Valves .....	8
3.2.7	Siphon Tubes .....	9
3.2.8	Pressure Relief Devices .....	9
3.2.9	Discharge Heads and Connectors .....	9
3.2.10	Manifolds and Piping.....	9
3.2.11	Cylinder Supports.....	9
3.2.12	Protective Covering .....	9
3.2.13	Actuation Devices or Control Heads .....	10
3.2.14	Auxiliary Manual Controls.....	10
3.2.15	Selector and Lockout Valves .....	10
3.2.16	Nozzles .....	10
3.2.17	Nozzle Screens .....	10
3.2.18	Nozzle Covers.....	11
3.2.19	Carbon Dioxide.....	11
3.2.20	Auxiliary Equipment .....	11
3.2.21	Low Pressure Agent Supply Container Configuration Requirements .....	12
3.2.22	Hazardous Location Rating of Components.....	13
3.3	Markings.....	13
3.4	Manufacturer's Installation and Operation Instructions .....	14
3.5	Calibration.....	14
<b>4.</b>	<b>PERFORMANCE REQUIREMENTS .....</b>	<b>15</b>
4.1	One Year Leakage Test for High Pressure Supply Containers.....	15
4.2	Leakage at Maximum and Minimum Storage Temperature Test for High Pressure Supply Containers .....	15
4.3	Equivalent Length and Nozzle Size Number Determination.....	16
4.4	High Rate of Flow Discharge Integrity.....	16
4.5	Cycle Operation Test .....	17
4.6	Valve Leakage.....	18
4.7	Hydrostatic Integrity.....	18
4.8	Pressure Relief Devices .....	19
4.8.1	Pressure Relief Operation .....	19
4.8.2	Pressure Relief Calculations .....	19

<b>4.9</b>	<b>Flexible Hose</b> .....	<b>20</b>
4.9.1	Low Temperature Resistance.....	20
4.9.2	Resilience.....	20
<b>4.10</b>	<b>Actuator and Control Operation</b> .....	<b>21</b>
4.10.1	General.....	21
4.10.2	Electrically Operated Devices.....	21
4.10.3	Manually Operated Controls.....	21
4.10.4	Pilot Operated Controls.....	22
4.10.5	Mechanical Time Delay Assemblies.....	22
4.10.6	Pressure Operated Audible Alarm Devices.....	22
<b>4.11</b>	<b>Dielectric Withstand</b> .....	<b>23</b>
<b>4.12</b>	<b>Salt Fog Corrosion</b> .....	<b>23</b>
<b>4.13</b>	<b>Individual Component Functionality</b> .....	<b>23</b>
4.13.1	General.....	23
4.13.2	Stress Corrosion.....	24
4.13.3	Thermal Shock.....	25
4.13.4	Elastomeric Materials Tests.....	25
<b>4.14</b>	<b>Temperature Maintenance for Low Pressure Storage Containers</b> .....	<b>26</b>
<b>4.15</b>	<b>Pressure Gauge (Low Pressure)</b> .....	<b>27</b>
4.15.1	Accuracy.....	27
4.15.2	Impulse Resistance.....	27
<b>4.16</b>	<b>Liquid Level Indicator (Low Pressure)</b> .....	<b>27</b>
<b>4.17</b>	<b>Area of Coverage for Total Flooding Systems</b> .....	<b>27</b>
<b>4.18</b>	<b>Area of Coverage for Overhead Local Application Systems</b> .....	<b>29</b>
<b>4.19</b>	<b>Carbon Dioxide Calculation Method</b> .....	<b>30</b>
<b>4.20</b>	<b>Protection of Wet Benches and Similar Processing Equipment</b> .....	<b>31</b>
<b>4.21</b>	<b>Additional Tests</b> .....	<b>31</b>
<b>5.</b>	<b>OPERATIONS REQUIREMENTS</b> .....	<b>32</b>
5.1	Demonstrated Quality Control Program.....	32
5.2	Surveillance Audit.....	33
5.3	Manufacturer's Responsibilities.....	33
5.4	Manufacturing and Production.....	33
<b>APPENDIX A:</b> .....		<b>35</b>
<b>APPENDIX B:</b> .....		<b>35</b>
<b>APPENDIX C: Component Examination Guide</b> .....		<b>36</b>
<b>APPENDIX D. Sample Listing</b> .....		<b>38</b>
<b>APPENDIX E. Fire tests for Carbon Dioxide Extinguishing Systems for the Protection of Wet Benches and Similar Processing Equipment</b> .....		<b>39</b>
<b>E.1</b>	<b>General Testing Requirements</b> .....	<b>39</b>
<b>E.2</b>	<b>Ventilated Subsurface (Plenum) Fire Tests (Figures E-3, E-5 and E-6)</b> .....	<b>39</b>
E.2.1	Nominal 4 in. (102 mm) Diameter Polypropylene Pool Fire.....	39
E.2.2	Nominal 6 in. (152 mm) Diameter Polypropylene Pool Fire.....	40
E.2.3	Nominal 8 in. (203 mm) Diameter Polypropylene Pool Fire.....	40
E.2.4	Nominal 10 in. (254 mm) Diameter Polypropylene Pool Fire.....	40
E.2.5	Nominal 12 in. (305 mm) Diameter Polypropylene Pool Fire.....	40
E.2.6	Flammable Liquid Pool Fires.....	40
<b>E.3</b>	<b>Wet Bench Working Surface Fire Tests (Figures E-1 through E-4 and E-7)</b> .....	<b>41</b>
E.3.1	Nominal 4 in. (102 mm) Diameter Polypropylene Pool Fire.....	41
E.3.2	Nominal 6 in. (152 mm) Diameter Polypropylene Pool Fire.....	41
E.3.3	Nominal 8 in. (203 mm) Diameter Polypropylene Pool Fire.....	41
E.3.4	Nominal 10 in. (254 mm) Diameter Polypropylene Pool Fire.....	41
E.3.5	Nominal 12 in. (305 mm) Diameter Polypropylene Pool Fire.....	42
E.3.6	Flammable Liquid Pool Fires.....	42
E.3.7	Splashing Test.....	42



E.3.8 Other Working Surface Fire Tests .....	42
Figure E-1. Clean Room Simulation Facility - Side View.....	43
Figure E-2. Clean Room Simulation Facility - Top View .....	44
Figure E-3. Clean Room Simulation Facility - Front View .....	45
Figure E-4. Wet Bench Test Apparatus - Side View .....	46
Figure E-5. Wet Bench Test Apparatus for Plenum Fire Subsurface Testing with Obstructions- Front View.....	47
Figure E-6. Wet Bench Test Apparatus for Plenum Fire Subsurface Testing without Obstructions- Front View.....	48
Figure E-7. Wet Bench Test Apparatus for Surface Area Fire Testing- Front View .....	49
Figure E-8. Polypropylene Pool Fire for Wet Bench Fire Testing.....	50
<b>APPENDIX F: Figures.....</b>	<b>51</b>
Figure F-1. Test Enclosure for Total Flooding Systems .....	51

## 1. INTRODUCTION

### 1.1 Purpose

- 1.1.1 This standard states testing and certification requirements for fixed fire extinguishing systems which use carbon dioxide (CO<sub>2</sub>) as the extinguishant.
- 1.1.2 Testing and certification criteria may include, but are not limited to, performance requirements, marking requirements, examination of manufacturing facility(ies), audit of quality assurance procedures, and a surveillance program.

### 1.2 Scope

- 1.2.1 CO<sub>2</sub> systems are classed in two general categories according to hazard coverage design, total flooding or local application. Either type shall be designed for automatic and manual control to protect single or multiple hazard areas.
- 1.2.2 A basic CO<sub>2</sub> extinguishing system comprises one or more agent supply containers; discharge control valves arranged for automatic (or both automatic and manual) control; lock-out valves; piping; and discharge nozzles. Compatible certified detectors and detection and release controls are required for automatic operation of these systems, but are not included in the scope of this standard.
- 1.2.3 This standard requires the examination of complete systems. Complete systems shall be submitted along with design, installation, operation, and maintenance instructions for certification. However, the manufacturer may, at any time, submit additional separate component parts or auxiliary equipment for use on his system. Purchased devices such as thermostats, releases, and timers must also be submitted by the system manufacturer for evaluation as a part of his system, even though such devices may already be certified and listed by a certification agency. At minimum, a system shall consist of those component parts and auxiliary equipment considered necessary by the certification agency for the system to operate satisfactorily. Incomplete systems shall not be certified.

### 1.3 Basis for Requirements

- 1.3.1 The requirements of this standard are based on experience, research and testing, and/or the standards of other organizations. The advice of manufacturers, users, trade associations, jurisdictions and/or loss control specialists was also considered.
- 1.3.2 The requirements of this standard reflect tests and practices used to examine characteristics of CO<sub>2</sub> fire extinguishing systems (hereinafter referred to as “systems”) for the purpose of obtaining certification. Systems having characteristics not anticipated by this standard may be certified if performance equal, or superior, to that required by this standard is demonstrated.